

**बिड दस्तावेज़ / Bid Document**

बिड विवरण / Bid Details	
बिड बंद होने की तारीख/समय / Bid End Date/Time	05-12-2025 10:00:00
बिड खुलने की तारीख/समय / Bid Opening Date/Time	05-12-2025 10:30:00
बिड पेशकश वैधता (बंद होने की तारीख से) / Bid Offer Validity (From End Date)	90 (Days)
मंत्रालय/राज्य का नाम / Ministry/State Name	Ministry Of Defence
विभाग का नाम / Department Name	Department Of Military Affairs
संगठन का नाम / Organisation Name	Indian Army
कार्यालय का नाम / Office Name	*****
कुल मात्रा / Total Quantity	3472
वस्तु श्रेणी / Item Category	Curtain Pipe, Sider and mounting bracket (Q4) , Propeller Type AC Ventilating Fans - Exhaust Fans (V2) as per IS 2312 (Q2) , LED Batten (Q2) , Molded Case Circuit Breakers (MCCB) as per IS / IEC 60947 (Q3) , XLPE Cable for Working Voltages up to and Including 1.1 KV as per IS 7098 (Part 1) (Q2) , MCB - Miniature Circuit - Breakers for A.C. Operation as per IS / IEC 60898 (Part 1) (Q2) , Towel Rail / Ring for Bathroom (Q3) , Tower Bolts (Ferrous Metals) as per IS 204 (Q3) , Plastics Bib Taps Pillar Taps Angle Valves and Stop Valves as per IS 9763:2000 (Latest) (Q3) , Connection Pipe with Nuts (V2) (Q3) , Waste Pipe (Q3) , Flushing Cistern (Q3) , HYDRAULICALLY REGULATED DOOR CLOSERS (Q3) , Toilet Seat Covers (V2) (Q4) , Metal Alloy Casting Water Tap with Aerator (V2) (Q3) , Waste Fittings for Washbasin and Sinks as per IS 2963 (Q3) , M - Seal as per IS 9197 (Q3) , Cast Copper Alloy Screw Down Bib Taps and Stop Valves for Water Services as per IS 781 (Q3) , European Pattern Toilet Seat Vitreous China (Q3) , Sinks / Wash Basins - Vitreous China as per IS 2556 (Part 4) (Q3) , Piano Type Modular Domestic Fan Regulator as per IS 11037 (Q3) , Piano Type Non Modular Electrical Switch Socket Combination as per IS 3854 and IS 1293 (Q3) , Modular Piano Type Domestic Electrical Switches as per IS 3854 (Q3)
उन्हीं/समान सेवा के लिए अपेक्षित विगत अनुभव के वर्ष / Years of Past Experience Required for same/similar service	3 Year (s)
टर्नओवर के लिए एमएसई को छूट प्राप्त है / MSE Exemption for Turnover	Yes   Complete
टर्नओवर के लिए स्टार्टअप को छूट प्राप्त है / Startup Exemption for Turnover	Yes   Complete

बिड विवरण/Bid Details	
विक्रेता से मांगे गए दस्तावेज़/Document required from seller	Experience Criteria,Past Performance,Bidder Turnover,Certificate (Requested in ATC),OEM Authorization Certificate,OEM Annual Turnover,Additional Doc 1 (Requested in ATC) *In case any bidder is seeking exemption from Experience / Turnover Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer
क्या आप निविदाकारों द्वारा अपलोड किए गए दस्तावेजों को निविदा में भाग लेने वाले सभी निविदाकारों को दिखाना चाहते हैं? संदर्भ मेनू है/Do you want to show documents uploaded by bidders to all bidders participated in bid?	No
बिड लगाने की समय सीमा स्वतः नहीं बढ़ाने के लिए आवश्यक बिड की संख्या। / Minimum number of bids required to disable automatic bid extension	4
दिनों की संख्या, जिनके लिए बिड लगाने की समय-सीमा बढ़ाई जाएगी। / Number of days for which Bid would be auto-extended	3
ऑटो एक्सटेंशन अधिकतम कितनी बार किया जाना है। / Number of Auto Extension count	1
विगत प्रदर्शन /Past Performance	40 %
बिड से रिवर्स नीलामी सक्रिय किया/Bid to RA enabled	Yes
रिवर्स नीलामी योग्यता नियम/RA Qualification Rule	50% Lowest Priced Technically Qualified Bidders
बिड का प्रकार/Type of Bid	Two Packet Bid
प्राथमिक उत्पाद श्रेणी/Primary product category	Waste Pipe
तकनीकी मूल्यांकन के दौरान तकनीकी स्पष्टीकरण हेतु अनुमत समय /Time allowed for Technical Clarifications during technical evaluation	2 Days
निरीक्षण आवश्यक (सूचीबद्ध निरीक्षण प्राधिकरण /जेम के साथ पूर्व पंजीकृत एजेंसियों द्वारा)/Inspection Required (By Empanelled Inspection Authority / Agencies pre-registered with GeM)	No
मूल्यांकन पद्धति/Evaluation Method	Total value wise evaluation
मध्यस्थता खंड/Arbitration Clause	No
सुलह खंड/Mediation Clause	No

#### ईएमडी विवरण/EMD Detail

एडवाइजरी बैंक/Advisory Bank	State Bank of India
ईएमडी राशि/EMD Amount	115000

**ईपीबीजी विवरण /ePBG Detail**

एडवाइजरी बैंक/Advisory Bank	State Bank of India
ईपीबीजी प्रतिशत (%) /ePBG Percentage(%)	3.00
ईपीबीजी की आवश्यक अवधि (माह) /Duration of ePBG required (Months).	3

(a). जेम की शर्तों के अनुसार ईएमडी छूट के इच्छुक बिडर को संबंधित कैटेगरी के लिए बिड के साथ वैध समर्थित दस्तावेज प्रस्तुत करने है। एमएसई कैटेगरी के अंतर्गत केवल वस्तुओं के लिए विनिर्माता तथा सेवाओं के लिए सेवा प्रदाता ईएमडी से छूट के पात्र हैं। व्यापारियों को इस नीति के दायरे से बाहर रखा गया है।/EMD EXEMPTION: The bidder seeking EMD exemption, must submit the valid supporting document for the relevant category as per GeM GTC with the bid. Under MSE category, only manufacturers for goods and Service Providers for Services are eligible for exemption from EMD. Traders are excluded from the purview of this Policy.

(b).ईएमडी और संपादन जमानत राशि, जहां यह लागू होती है, लाभार्थी के पक्ष में होनी चाहिए। / EMD & Performance security should be in favour of Beneficiary, wherever it is applicable.

**लाभार्थी /Beneficiary :**

Offg SBSO

CWE SUBS MUMBAI, Department of Military Affairs, Indian Army, Ministry of Defence  
(Kanchan Harishchandra Salvi)

बोली विभाजन लागू नहीं किया गया/ Bid splitting not applied.

**एमआईआई खरीद वरीयता / MII Purchase Preference**

एमआईआई खरीद वरीयता / MII Purchase Preference	Yes
मेक इन इंडिया विक्रेताओं को खरीद में प्राथमिकता, यदि उनका मूल्य $L1+X\%$ तक की सीमा में है / Purchase Preference to MII sellers available upto price within $L1+X\%$	20
मेक इन इंडिया खरीद में प्राथमिकता के लिए बिड की मात्रा का अधिकतम प्रतिशत / Maximum Percentage of Bid quantity for MII purchase preference	50
सार्वजनिक खरीद (मेक-इन-इंडिया को प्राथमिकता) आदेश 2017 के अनुसार केवल क्लास 1/क्लास 2 के स्थानीय आपूर्तिकर्ताओं को ही भागीदारी की अनुमति है दिनांक 16.09.2020 (समय-समय पर संशोधित एवं लागू) / Allow participation only from Class 1/Class 2 local suppliers as per the Public procurement(Preference to Make-in-india) order 2017 date 16.09.2020(as amended and applicable time to time)	Yes, in compliance with the MII ORDER : DPIIT Order(as amended and applicable time to time)

**एमएसई खरीद वरीयता/MSE Purchase Preference**

एमएसई खरीद वरीयता/MSE Purchase Preference	Yes
सूक्ष्म और लघु उद्यम मूल उपकरण निर्माताओं को खरीद में प्राथमिकता, यदि उनका मूल्य $L1+X\%$ तक की सीमा में हो / Purchase Preference to MSE OEMs available upto price within $L1+X\%$	15
सूक्ष्म और लघु उद्यम को खरीद में प्राथमिकता के लिए बिड की मात्रा का अधिकतम प्रतिशत / Maximum Percentage of Bid quantity for MSE purchase preference	25

1. If the bidder is a Micro or Small Enterprise (MSE) as per latest orders issued by Ministry of MSME, the bidder shall be exempted from the eligibility criteria of "Bidder Turnover" as defined above subject to meeting of quality and technical specifications. If the bidder itself is MSE OEM of the offered products, it would be exempted from the "OEM Average Turnover" criteria also subject to meeting of quality and technical specifications. The bidder seeking exemption from Turnover, shall upload the supporting documents to prove his eligibility for exemption.

2. If the bidder is a DPIIT registered Startup, the bidder shall be exempted from the the eligibility criteria of "Bidder Turnover" as defined above subject to their meeting of quality and technical specifications. If the bidder is DPIIT Registered OEM of the offered products, it would be exempted from the "OEM Average Turnover" criteria also subject to meeting of quality and technical specifications. The bidder seeking exemption from Turnover shall upload the supporting documents to prove his eligibility for exemption.

3. Experience Criteria: In respect of the filter applied for experience criteria, the Bidder or its OEM of the product offered in the bid {themselves or through reseller(s)} should have regularly, manufactured and supplied same or similar Category Products to any Central / State Govt Organization / PSU for number of Financial years as indicated above in the bid document before the bid opening date. Copies of relevant contracts and delivery acceptance certificates like CRAC to be submitted along with bid in support of having supplied some quantity during each of the Financial year. In case of bunch bids, the category of primary product having highest value should meet this criterion.

4. Preference to Make In India products (For bids < 200 Crore): Preference shall be given to Class 1 local supplier as defined in public procurement (Preference to Make in India), Order 2017 as amended from time to time and its subsequent Orders/Notifications issued by concerned Nodal Ministry for specific Goods/Products. The minimum local content to qualify as a Class 1 local supplier is denoted in the bid document. If the bidder wants to avail the Purchase preference, the bidder must upload a certificate from the OEM regarding the percentage of the local content and the details of locations at which the local value addition is made along with their bid, failing which no purchase preference shall be granted. In case the bid value is more than Rs 10 Crore, the declaration relating to percentage of local content shall be certified by the statutory auditor or cost auditor, if the OEM is a company and by a practicing cost accountant or a chartered accountant for OEMs other than companies as per the Public Procurement (preference to Make-in -India) order 2017 dated 04.06.2020. Only Class-I and Class-II Local suppliers as per MII order dated 4.6.2020 will be eligible to bid. Non - Local suppliers as per MII order dated 04.06.2020 are not eligible to participate. However, eligible micro and small enterprises will be allowed to participate .The buyers are advised to refer the OM No.F.1/4/2021-PPD dated 18.05.2023.

[OM No.1 4 2021 PPD dated 18.05.2023](#) for compliance of Concurrent application of Public Procurement Policy for Micro and Small Enterprises Order, 2012 and Public Procurement (Preference to Make in India) Order, 2017.

5. Purchase preference will be given to MSEs having valid Udyam Registration and whose credentials are validated online through Udyam Registration portal as defined in Public Procurement Policy for Micro and Small Enterprises (MSEs) Order, 2012 dated 23.03.2012 issued by Ministry of Micro, Small and Medium Enterprises and its subsequent Orders/Notifications issued by concerned Ministry. If the bidder wants to avail themselves of the Purchase preference, the bidder must be the manufacturer / OEM of the offered product on GeM. Traders are excluded from the purview of Public Procurement Policy for Micro and Small Enterprises and hence resellers offering products manufactured by some other OEM are not eligible for any purchase preference. In respect of bid for Services, the bidder must be the Service provider of the offered Service. Relevant documentary evidence in this regard shall be uploaded along with the bid in respect of the offered product or service and Buyer will decide eligibility for purchase preference based on documentary evidence submitted, while evaluating the bid. If L-1 is not an MSE and MSE Seller (s) has / have quoted price within  $L-1+ 15\%$  (Selected by Buyer) of margin of purchase preference /price band defined in relevant policy, such MSE Seller shall be given opportunity to match L-1 price and contract will be awarded for 25% (selected by Buyer) percentage of total quantity. The buyers are advised to refer the OM No. F.1/4/2021-PPD dated 18.05.2023 [OM No.1 4 2021 PPD dated 18.05.2023](#) for compliance of Concurrent application of Public Procurement Policy for Micro and Small Enterprises Order, 2012

and Public Procurement (Preference to Make in India) Order, 2017. Benefits of MSE will be allowed only if seller is validated on-line in GeM profile as well as validated and approved by Buyer after evaluation of documents submitted.

6. Estimated Bid Value indicated above is being declared solely for the purpose of guidance on EMD amount and for determining the Eligibility Criteria related to Turn Over, Past Performance and Project / Past Experience etc. This has no relevance or bearing on the price to be quoted by the bidders and is also not going to have any impact on bid participation. Also this is not going to be used as a criteria in determining reasonableness of quoted prices which would be determined by the buyer based on its own assessment of reasonableness and based on competitive prices received in Bid / RA process.

7. Past Performance: The Bidder or its OEM {themselves or through re-seller(s)} should have supplied same or similar Category Products for 40% of bid quantity, in at least one of the last three Financial years before the bid opening date to any Central / State Govt Organization / PSU. Copies of relevant contracts (proving supply of cumulative order quantity in any one financial year) to be submitted along with bid in support of quantity supplied in the relevant Financial year. In case of bunch bids, the category related to primary product having highest bid value should meet this criterion.

8. Short Duration Bid has been published by the Buyer with the approval of the Competent authority due to Emergency procurement of critical products/services.

9. Reverse Auction would be conducted amongst first 50% of the technically qualified bidders arranged in the order of prices from lowest to highest. Number of sellers eligible for participating in RA would be rounded off to next higher integer value if number of technically qualified bidders is odd (e.g. if 7 bids are technically qualified, then RA will be conducted amongst L-1 to L-4). In case number of technically qualified bidders are 2 or 3, RA will be between all without any elimination. If Buyer has chosen to split the bid amongst N sellers, then minimum N sellers would be taken to RA round. In case Primary products of only one OEM are left in contention for participation in RA based on lowest 50% bidders qualifying for RA, the number of sellers qualifying for RA would be increased to get at least products of one more OEM (directly participated or through its reseller) if available. Further, if bid(s) of any seller(s) eligible for MSE preference is / are coming within price band of 15% of Non MSE L-1 or if bid of any seller(s) eligible for Make in India preference is / are coming within price band of 20% of non MII L-1, then such MSE / Make in India seller shall also be allowed to participate in the RA process.

### **Curtain Pipe, Sider And Mounting Bracket ( 50 meter )**

**(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)**

#### **तकनीकी विशिष्टियाँ /Technical Specifications**

[\\* जेम कैटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
ITEM	ITEM	Hanging Bracket
OTHER REQUIREMENTS	Sider(one pair per pipe)	Without
DIMENSON	Outside Diameter of curtain pipe (in mm)	19mm
	Length of curtain pipe( In Meter)	1
	Minimum Wall thickness of pipe ( In MM)	1, 2, 3, 4, 5 Or higher
	Minimum thickness of Curtain pipe hanging bracket (in mm)	2, 3 Or higher

**Additional Specification Parameters - Curtain Pipe, Sider And Mounting Bracket ( 50 meter )**

Specification Parameter Name	Bid Requirement (Allowed Values)
as per requirement: CROWN/ LOTUS /GODREJ	as per requirement: CROWN/ LOTUS /GODREJ

\* Bidders offering must also comply with the additional specification parameters mentioned above.

**परिषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity**

क्र.सं./S.No.	परिषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****MUMBAI	50	60

**Propeller Type AC Ventilating Fans - Exhaust Fans (V2) As Per IS 2312 ( 10 pieces )**

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

Bis Required	Yes
--------------	-----

**तकनीकी विशिष्टियाँ /Technical Specifications**

[\\* जेम कैटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
STANDARD	ISI Marked Product	YES, NO Or higher
GENERIC	Size of fan (in mm)	300.0
	Number of pole (in Nos.)	4.0
	Number of blades	4
	Speed regulator	Yes, No Or higher
	Rated voltage	230 V, 50 HZ, AC, Single Phase
CONSTRUCTION	Type of Fan	Capacitor Type
	Class of insulation	Class E
ENCLOSURES	Provision of Guards for	Outlet side
CERTIFICATION	Warranty period (in Years)	2 Or higher

**Additional Specification Parameters - Propeller Type AC Ventilating Fans - Exhaust Fans (V2) As Per IS 2312 ( 10 pieces )**

Specification Parameter Name	Bid Requirement (Allowed Values)
as per requirement : BAJAJ /ORIENT ELECTRIC/ SURYA	as per requirement : BAJAJ /ORIENT ELECTRIC/ SURYA

\* Bidders offering must also comply with the additional specification parameters mentioned above.

**परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity**

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****MUMBAI	10	60

**Propeller Type AC Ventilating Fans - Exhaust Fans (V2) As Per IS 2312 ( 10 pieces )**

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

Bis Required	Yes
--------------	-----

**तकनीकी विशिष्टियाँ /Technical Specifications**

\* जेम कैटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
STANDARD	ISI Marked Product	YES, NO Or higher
GENERIC	Size of fan (in mm)	450.0
	Number of pole (in Nos.)	6.0
	Number of blades	3
	Speed regulator	Yes, No Or higher
	Rated voltage	230 V, 50 HZ, AC, Single Phase
CONSTRUCTION	Type of Fan	Capacitor Type
	Class of insulation	Class E
ENCLOSURES	Provision of Guards for	Without Guard
CERTIFICATION	Warranty period (in Years)	2 Or higher

**Additional Specification Parameters - Propeller Type AC Ventilating Fans - Exhaust Fans (V2) As Per IS 2312 ( 10 pieces )**

Specification Parameter Name	Bid Requirement (Allowed Values)
as per requirement : BAJAJ /ORIENT ELECTRIC/ SURYA	as per requirement : BAJAJ /ORIENT ELECTRIC/ SURYA

\* Bidders offering must also comply with the additional specification parameters mentioned above.

**परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity**

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****MUMBAI	10	60

**LED Batten ( 200 pieces )**

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

**तकनीकी विशिष्टियाँ /Technical Specifications**

\* जेम कैटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	<b>LED Batten Rating (in Watts)</b>	10.0
	<b>Length of LED Batten (Nominal) (in mm)</b>	560.0
	<b>Lamp Efficacy (Lumen / Watt), Minimum</b>	110 Or higher
	LED chip Efficacy (Lumen / Watt), Minimum	130
	Colour Temperature (in K)	6500 (Cool white)
	<b>Warranty for free replacement (in Years)</b>	3 Or higher
CONSTRUCTIONAL	<b>Housing Material</b>	Aluminium
	Colour Rendering Index (CRI) - Minimum	70, 80 Or higher

**Additional Specification Parameters - LED Batten ( 200 pieces )**



Specification Parameter Name	Bid Requirement (Allowed Values)
as per requirement :SURYA/ WIPRO /ORIENT ELECTRIC	as per requirement :SURYA/ WIPRO /ORIENT ELECTRIC

\* Bidders offering must also comply with the additional specification parameters mentioned above.

**परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity**

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****MUMBAI	200	60

**Molded Case Circuit Breakers (MCCB) As Per IS / IEC 60947 ( 4 pieces )**

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

**तकनीकी विशिष्टियाँ /Technical Specifications**

[\\* जेम कैटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	ISI marked	NO
	Rated Current (in Ampere)	400A
	No of poles/Protected poles(PP)	4 Pole
	Rated Short circuit capacity (in KA)	MCCB with RSCB capacity of 10/16/25/35/50/65 KA tripping range
	Breaking current (in KA)	50 KA
	Rated Voltage	220VDC

**Additional Specification Parameters - Molded Case Circuit Breakers (MCCB) As Per IS / IEC 60947 ( 4 pieces )**

Specification Parameter Name	Bid Requirement (Allowed Values)
as per requirement : LEGRAND/ C&S/ WIPRO	as per requirement : LEGRAND/ C&S/ WIPRO

\* Bidders offering must also comply with the additional specification parameters mentioned above.

**परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity**

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****MUMBAI	4	60

### LED Batten ( 250 pieces )

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

### तकनीकी विशिष्टियाँ /Technical Specifications

[\\* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	LED Batten Rating (in Watts)	20.0
	Length of LED Batten (Nominal) (in mm)	1150.0
	Lamp Efficacy (Lumen / Watt), Minimum	110 Or higher
	LED chip Efficacy (Lumen / Watt), Minimum	120
	Colour Temperature (in K)	6500 (Cool white)
	Warranty for free replacement (in Years)	2, 3 Or higher
CONSTRUCTIONAL	Housing Material	Aluminium
	Colour Rendering Index (CRI) - Minimum	70, 80 Or higher
	Total Harmonics (%), Maximum	15, 20 Or lower
	Operating Voltage range (in Volts)	140 to 270

### Additional Specification Parameters - LED Batten ( 250 pieces )

Specification Parameter Name	Bid Requirement (Allowed Values)
as per requirement : SURYA/ WIPRO /ORIENT ELECTRIC	as per requirement : SURYA/ WIPRO /ORIENT ELECTRIC

\* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****MUMBAI	250	60

### Molded Case Circuit Breakers (MCCB) As Per IS / IEC 60947 ( 5 pieces )

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

#### तकनीकी विशिष्टियाँ /Technical Specifications

[\\* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	ISI marked	NO
	Rated Current (in Ampere)	200A
	No of poles/Protected poles(PP)	3 Pole
	Rated Short circuit capacity (in KA)	35 KA
	Breaking current (in KA)	25 KA
	Rated Voltage	240/415 Volt 50 Hz AC

### Additional Specification Parameters - Molded Case Circuit Breakers (MCCB) As Per IS / IEC 60947 ( 5 pieces )

Specification Parameter Name	Bid Requirement (Allowed Values)
as per requirement :LEGRAND / C&S /WIPRO	as per requirement :LEGRAND / C&S /WIPRO

\* Bidders offering must also comply with the additional specification parameters mentioned above.

#### परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****MUMBAI	5	60

### Molded Case Circuit Breakers (MCCB) As Per IS / IEC 60947 ( 5 pieces )

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

## तकनीकी विशिष्टियाँ /Technical Specifications

\* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	ISI marked	NO
	Rated Current (in Ampere)	250A
	No of poles/Protected poles(PP)	3 Pole
	Rated Short circuit capacity (in KA)	MCCB with RSCB capacity 10/16 KA tripping range
	Breaking current (in KA)	25 KA
	Rated Voltage	415 volt 50 Hz

## Additional Specification Parameters - Molded Case Circuit Breakers (MCCB) As Per IS / IEC 60947 ( 5 pieces )

Specification Parameter Name	Bid Requirement (Allowed Values)
as per requirement :LEGRAND / C&S /WIPRO	as per requirement :LEGRAND / C&S /WIPRO

\* Bidders offering must also comply with the additional specification parameters mentioned above.

## परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****MUMBAI	5	60

## Molded Case Circuit Breakers (MCCB) As Per IS / IEC 60947 ( 4 pieces )

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

## तकनीकी विशिष्टियाँ /Technical Specifications

\* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	ISI marked	NO
	Rated Current (in Ampere)	160A

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
	No of poles/Protected poles(PP)	4 Pole
	Rated Short circuit capacity (in KA)	MCCB with RSCB capacity 10/16 KA tripping range
	Breaking current (in KA)	25 KA
	Rated Voltage	240 Volt 50 Hz AC

**Additional Specification Parameters - Molded Case Circuit Breakers (MCCB) As Per IS / IEC 60947 ( 4 pieces )**

Specification Parameter Name	Bid Requirement (Allowed Values)
as per requirement :LEGRAND / C&S /WIPRO	as per requirement :LEGRAND / C&S /WIPRO

\* Bidders offering must also comply with the additional specification parameters mentioned above.

**परिषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity**

क्र.सं./S.No.	परिषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****MUMBAI	4	60

**XLPE Cable For Working Voltages Up To And Including 1.1 KV As Per IS 7098 (Part 1) ( 180 meter )**

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

Bis Required	Yes
--------------	-----

**तकनीकी विशिष्टियाँ /Technical Specifications**

[\\* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
STANDARDS	Conformity of the specification for XLPE cable	as per IS:7098 (Part 1): 1988 latest
	Cables suitable for use in mines	No

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
	Cables suitable for use in low temperature applications	No
GENERIC	Classification of cables for improved fire performance category	C1 - FR
	Nominal Area of Conductor (in Sq mm)	95
	Number of core (in Nos)	3.5
CONSTRUCTION	Material of conductor	Aluminium
	Type of inner sheath	Thermoplastic
ARMOURING	Type of cable	Armoured cable
	Material of armouring	Galvanized steel formed wire
	Type of armouring	Double wire
CERTIFICATION	Availability of Optional Test Reports	Cold bend test for outer sheath, Cold impact test for outer sheath, Resistance test for Armour, Not applicable

**Additional Specification Parameters - XLPE Cable For Working Voltages Up To And Including 1.1 KV As Per IS 7098 (Part 1) ( 180 meter )**

Specification Parameter Name	Bid Requirement (Allowed Values)
as per requirement :GRANDLAY /PLAZA /:LEGRAND	as per requirement :GRANDLAY /PLAZA /LEGRAND

\* Bidders offering must also comply with the additional specification parameters mentioned above.

**परिषेती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity**

क्र.सं./S.No.	परिषेती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****MUMBAI	180	60

**XLPE Cable For Working Voltages Up To And Including 1.1 KV As Per IS 7098 (Part 1) ( 200 meter )**

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

Bis Required	Yes
--------------	-----

## तकनीकी विशिष्टियाँ /Technical Specifications

\* जेम कैटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
STANDARDS	Conformity of the specification for XLPE cable	as per IS:7098 (Part 1): 1988 latest
	Cables suitable for use in mines	Yes
	Cables suitable for use in low temperature applications	No
GENERIC	Classification of cables for improved fire performance category	01
	Nominal Area of Conductor (in Sq mm)	70
	Number of core (in Nos)	3.5
CONSTRUCTION	Material of conductor	Aluminium
	Type of inner sheath	Thermoplastic
ARMOURING	Type of cable	Armoured cable
	Material of armouring	Galvanized round steel wire
	Type of armouring	Single wire
CERTIFICATION	Availability of Optional Test Reports	Cold bend test for outer sheath, Cold impact test for outer sheath, Resistance test for Armour, Not applicable

### Additional Specification Parameters - XLPE Cable For Working Voltages Up To And Including 1.1 KV As Per IS 7098 (Part 1) ( 200 meter )

Specification Parameter Name	Bid Requirement (Allowed Values)
as per requirement :GRANDLAY /PLAZA /LEGRAND	as per requirement :GRANDLAY /PLAZA /LEGRAND

\* Bidders offering must also comply with the additional specification parameters mentioned above.

### परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
---------------	---	-------------	------------------	------------------------------

क्र.सं./S.No.	प्रेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****MUMBAI	200	60

### XLPE Cable For Working Voltages Up To And Including 1.1 KV As Per IS 7098 (Part 1) ( 200 meter )

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

Bis Required	Yes
--------------	-----

### तकनीकी विशिष्टियाँ /Technical Specifications

[\\* जेम कैटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
STANDARDS	Conformity of the specification for XLPE cable	as per IS:7098 (Part 1): 1988 latest
	Cables suitable for use in mines	No
	Cables suitable for use in low temperature applications	Yes
GENERIC	Classification of cables for improved fire performance category	C2 - FR-LSH
	Nominal Area of Conductor (in Sq mm)	50
	Number of core (in Nos)	3.5
CONSTRUCTION	Material of conductor	Aluminium
	Type of inner sheath	Thermoplastic
ARMOURING	Type of cable	Armoured cable
	Material of armouring	Aluminium flat strip
	Type of armouring	Single strip
CERTIFICATION	Availability of Optional Test Reports	Cold bend test for outer sheath, Cold impact test for outer sheath, Resistance test for Armour, Not applicable

**Additional Specification Parameters - XLPE Cable For Working Voltages Up To And Including 1.1 KV As Per IS 7098 (Part 1) ( 200 meter )**



Specification Parameter Name	Bid Requirement (Allowed Values)
as per requirement :GRANDLAY /PLAZA /LEGRAND	as per requirement :GRANDLAY /PLAZA /LEGRAND

\* Bidders offering must also comply with the additional specification parameters mentioned above.

**प्रेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity**

क्र.सं./S.No.	प्रेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****MUMBAI	200	60

**XLPE Cable For Working Voltages Up To And Including 1.1 KV As Per IS 7098 (Part 1) ( 200 meter )**

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

Bis Required	Yes
--------------	-----

**तकनीकी विशिष्टियाँ /Technical Specifications**

[\\* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
STANDARDS	Conformity of the specification for XLPE cable	as per IS:7098 (Part 1): 1988 latest
	Cables suitable for use in mines	No
	Cables suitable for use in low temperature applications	Yes
GENERIC	Classification of cables for improved fire performance category	01
	Nominal Area of Conductor (in Sq mm)	35
	Number of core (in Nos)	3.5
CONSTRUCTION	Material of conductor	Aluminium
	Type of inner sheath	Thermoplastic
ARMOURING	Type of cable	Armoured cable
	Material of armouring	Galvanized steel formed wire
	Type of armouring	Single strip

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
CERTIFICATION	Availability of Optional Test Reports	Not applicable

**Additional Specification Parameters - XLPE Cable For Working Voltages Up To And Including 1.1 KV As Per IS 7098 (Part 1) ( 200 meter )**

Specification Parameter Name	Bid Requirement (Allowed Values)
as per requirement :GRANDLAY /PLAZA/ LEGRAND	as per requirement :GRANDLAY /PLAZA /LEGRAND

\* Bidders offering must also comply with the additional specification parameters mentioned above.

**परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity**

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****MUMBAI	200	60

**XLPE Cable For Working Voltages Up To And Including 1.1 KV As Per IS 7098 (Part 1) ( 200 meter )**

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

Bis Required	Yes
--------------	-----

**तकनीकी विशिष्टियाँ /Technical Specifications**

[\\* जेम कैटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
STANDARDS	Conformity of the specification for XLPE cable	as per IS:7098 (Part 1): 1988 latest
	Cables suitable for use in mines	Yes
	Cables suitable for use in low temperature applications	Yes
GENERIC	Classification of cables for improved fire performance category	01

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
	Nominal Area of Conductor (in Sq mm)	25
	Number of core (in Nos)	3.5
CONSTRUCTION	Material of conductor	Aluminium
	Type of inner sheath	Thermoplastic
ARMOURING	Type of cable	Armoured cable
	Material of armouring	Aluminium flat strip
	Type of armouring	Double strip
CERTIFICATION	Availability of Optional Test Reports	Cold bend test for outer sheath, Cold impact test for outer sheath, Resistance test for Armour, Not applicable

**Additional Specification Parameters - XLPE Cable For Working Voltages Up To And Including 1.1 KV As Per IS 7098 (Part 1) ( 200 meter )**

Specification Parameter Name	Bid Requirement (Allowed Values)
as per requirement :GRANDLAY /PLAZA /LEGRAND	as per requirement :GRANDLAY /PLAZA /LEGRAND

\* Bidders offering must also comply with the additional specification parameters mentioned above.

**परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity**

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****MUMBAI	200	60

**MCB - Miniature Circuit - Breakers For A.C. Operation As Per IS / IEC 60898 (Part 1) ( 36 pieces )**

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

Bis Required	Yes
--------------	-----

**तकनीकी विशिष्टियाँ /Technical Specifications**

[\\* जेम कैटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
STANDARDS	Conformity of the specification	as per IS/IEC 60898 : PART 1:2015 latest
RATING	No. of pole (hint: "P" - Pole, "PP" Protected Pole)	1 P
	Rated voltage (in Volts)	230 / 415 V, AC
	Rated Current (in Ampere)	6
	Instantaneous tripping current type	D
	Rated Short circuit capacity (in Ampere)	10000
CONSTRUCTION	Provision of steel sheet enclosure duly pretreated stove enamelled/powder coated for MCBs	Without enclosure

**Additional Specification Parameters - MCB - Miniature Circuit - Breakers For A.C. Operation As Per IS / IEC 60898 (Part 1) ( 36 pieces )**

Specification Parameter Name	Bid Requirement (Allowed Values)
as per requirement :PANASONIC/ WIPRO /LEGRAND /C&S	as per requirement :PANASONIC/ WIPRO /LEGRAND /C&S

\* Bidders offering must also comply with the additional specification parameters mentioned above.

**परिषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity**

क्र.सं./S.No.	परिषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****MUMBAI	36	60

**MCB - Miniature Circuit - Breakers For A.C. Operation As Per IS / IEC 60898 (Part 1) ( 38 pieces )**

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

Bis Required	Yes
--------------	-----

**तकनीकी विशिष्टियाँ /Technical Specifications**

[\\* जेम कैटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
STANDARDS	Conformity of the specification	as per IS/IEC 60898 : PART 1:2015 latest
RATING	No. of pole (hint: "P" - Pole, "PP" Protected Pole)	2 P with 1 PP
	Rated voltage (in Volts)	230 / 415 V, AC
	Rated Current (in Ampere)	32
	Instantaneous tripping current type	D
	Rated Short circuit capacity (in Ampere)	10000
CONSTRUCTION	Provision of steel sheet enclosure duly pretreated stove enamelled/powder coated for MCBs	Without enclosure

**Additional Specification Parameters - MCB - Miniature Circuit - Breakers For A.C. Operation As Per IS / IEC 60898 (Part 1) ( 38 pieces )**

Specification Parameter Name	Bid Requirement (Allowed Values)
as per requirement :PANASONIC/ WIPRO /LEGRAND /C&S	as per requirement :PANASONIC/ WIPRO /LEGRAND /C&S

\* Bidders offering must also comply with the additional specification parameters mentioned above.

**परिषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity**

क्र.सं./S.No.	परिषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****MUMBAI	38	60

**MCB - Miniature Circuit - Breakers For A.C. Operation As Per IS / IEC 60898 (Part 1) ( 35 pieces )**

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

Bis Required	Yes
--------------	-----

**तकनीकी विशिष्टियाँ /Technical Specifications**

[\\* जेम कैटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
STANDARDS	Conformity of the specification	as per IS/IEC 60898 : PART 1:2015 latest
RATING	No. of pole (hint: "P" - Pole, "PP" Protected Pole)	2 P with 1 PP
	Rated voltage (in Volts)	230 / 415 V, AC
	Rated Current (in Ampere)	40
	Instantaneous tripping current type	D
	Rated Short circuit capacity (in Ampere)	10000
CONSTRUCTION	Provision of steel sheet enclosure duly pretreated stove enamelled/powder coated for MCBs	Without enclosure

**Additional Specification Parameters - MCB - Miniature Circuit - Breakers For A.C. Operation As Per IS / IEC 60898 (Part 1) ( 35 pieces )**

Specification Parameter Name	Bid Requirement (Allowed Values)
as per requirement :PANASONIC/ WIPRO /LEGRAND /C&S	as per requirement :PANASONIC/ WIPRO /LEGRAND /C&S

\* Bidders offering must also comply with the additional specification parameters mentioned above.

**परिषेती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity**

क्र.सं./S.No.	परिषेती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****MUMBAI	35	60

**MCB - Miniature Circuit - Breakers For A.C. Operation As Per IS / IEC 60898 (Part 1) ( 38 pieces )**

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

**तकनीकी विशिष्टियाँ /Technical Specifications**

[\\* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
STANDARDS	Conformity of the specification	as per IS/IEC 60898 : PART 1:2015 latest
RATING	No. of pole (hint: "P" - Pole, "PP" Protected Pole)	1 P
	Rated voltage (in Volts)	230 / 415 V, AC
	Rated Current (in Ampere)	16
	Instantaneous tripping current type	D
	Rated Short circuit capacity (in Ampere)	10000
CONSTRUCTION	Provision of steel sheet enclosure duly pretreated stove enamelled/powder coated for MCBs	Yes with 1.2 mm thick

**Additional Specification Parameters - MCB - Miniature Circuit - Breakers For A.C. Operation As Per IS / IEC 60898 (Part 1) ( 38 pieces )**

Specification Parameter Name	Bid Requirement (Allowed Values)
as per requirement :PANASONIC/ WIPRO /LEGRAND /C&S	as per requirement :PANASONIC/ WIPRO /LEGRAND /C&S

\* Bidders offering must also comply with the additional specification parameters mentioned above.

**परिषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity**

क्र.सं./S.No.	परिषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****MUMBAI	38	60

**MCB - Miniature Circuit - Breakers For A.C. Operation As Per IS / IEC 60898 (Part 1) ( 40 pieces )**

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

Bis Required	Yes
--------------	-----

**तकनीकी विशिष्टियाँ /Technical Specifications**

[\\* जेम कैटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
STANDARDS	Conformity of the specification	as per IS/IEC 60898 : PART 1:2015 latest
RATING	No. of pole (hint: "P" - Pole, "PP" Protected Pole)	1 P
	Rated voltage (in Volts)	230 / 415 V, AC
	Rated Current (in Ampere)	10
	Instantaneous tripping current type	D
	Rated Short circuit capacity (in Ampere)	10000
CONSTRUCTION	Provision of steel sheet enclosure duly pretreated stove enamelled/powder coated for MCBs	Without enclosure

**Additional Specification Parameters - MCB - Miniature Circuit - Breakers For A.C. Operation As Per IS / IEC 60898 (Part 1) ( 40 pieces )**

Specification Parameter Name	Bid Requirement (Allowed Values)
as per requirement :PANASONIC/ WIPRO /LEGRAND /C&S	as per requirement :PANASONIC/ WIPRO /LEGRAND /C&S

\* Bidders offering must also comply with the additional specification parameters mentioned above.

**परिषेती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity**

क्र.सं./S.No.	परिषेती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****MUMBAI	40	60

**Towel Rail / Ring For Bathroom ( 20 pieces )**

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

**तकनीकी विशिष्टियाँ /Technical Specifications**

[\\* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)



विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	Type of Fitting	Towel Ring
	Thickness of Ni-Cr coating	Not less than Service Condition Number 2 of Table 3 of IS 1068/1993
CONSTRUCTIONAL	Material	Stainless Steel(SS 202)
	Minimum Thickness of pipe	0.75 mm
	Color	Steel
	Shape	Ring
	Towel Ring Inner Diameter	150 mm
	Nominal Diameter of Pipe / Rod	20 mm
	Length of Towel Rail(mm)	NA
	Number of Mounting Bracket	1

#### Additional Specification Parameters - Towel Rail / Ring For Bathroom ( 20 pieces )

Specification Parameter Name	Bid Requirement (Allowed Values)
as per requirement :PRAYAG /PRIMA / CORONET	as per requirement :PRAYAG /PRIMA / CORONET

\* Bidders offering must also comply with the additional specification parameters mentioned above.

#### परिषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परिषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****MUMBAI	20	60

#### Towel Rail / Ring For Bathroom ( 25 pieces )

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

#### तकनीकी विशिष्टियाँ /Technical Specifications

[\\* जेम कैटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	Type of Fitting	Towel Rail
	Thickness of Ni-Cr coating	Not less than Service Condition Number 3 of Table 3 of IS 1068/1993
CONSTRUCTIONAL	Material	Cast Brass for Towel Rail
	Minimum Thickness of pipe	1.5 mm
	Color	Steel
	Shape	open rectangle
	Towel Ring Inner Diameter	N.A
	Nominal Diameter of Pipe / Rod	18 mm
	Length of Towel Rail(mm)	600
	Number of Mounting Bracket	2

#### Additional Specification Parameters - Towel Rail / Ring For Bathroom ( 25 pieces )

Specification Parameter Name	Bid Requirement (Allowed Values)
as per requirement :PRAYAG /PRIMA / CORONET	as per requirement :PRAYAG /PRIMA / CORONET

\* Bidders offering must also comply with the additional specification parameters mentioned above.

#### परेशिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेशिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****MUMBAI	25	60

#### Tower Bolts (Ferrous Metals) As Per IS 204 ( 50 pieces )

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

#### तकनीकी विशिष्टियाँ /Technical Specifications

[\\* जेम कैटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
ITEM	Item	"Barrel Tower Bolts (Type - 1A)"
SPECIFICATION	Conforming to Specification - no IS: 204 (Part 1), latest	Yes
FILTER	Shape of the Bolt	Half Round
	Fixing of knob with Bolt	Screwed
	Bolt's Finish	Bright Finished
	Other Part of Tower Bolt Finish	Bright Finished
DIMENSIONS	"Barrel Tower Bolts size (mm)"	100
	Semi-Barrel Tower Bolts size (mm)	100
	Riveted or Spot Welded Tower Bolts size (mm)	100
	"Skeleton Tower Bolts size (mm)"	NA

**Additional Specification Parameters - Tower Bolts (Ferrous Metals) As Per IS 204 ( 50 pieces )**

Specification Parameter Name	Bid Requirement (Allowed Values)
as per requirement :CROWN /LOTUS /GODREJ	as per requirement :CROWN /LOTUS /GODREJ

\* Bidders offering must also comply with the additional specification parameters mentioned above.

**परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity**

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****MUMBAI	50	60

**Tower Bolts (Ferrous Metals) As Per IS 204 ( 40 pieces )**

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

**तकनीकी विशिष्टियाँ /Technical Specifications**

[\\* जेम कैटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
ITEM	Item	"Barrel Tower Bolts (Type - 1B)"
SPECIFICATION	Conforming to Specification - no IS: 204 (Part 1), latest	Yes
FILTER	Shape of the Bolt	Round
	Fixing of knob with Bolt	Riveted
	Bolt's Finish	Bright
	Other Part of Tower Bolt Finish	Bright
DIMENSIONS	"Barrel Tower Bolts size (mm)"	150
	Semi-Barrel Tower Bolts size (mm)	150
	Riveted or Spot Welded Tower Bolts size (mm)	150
	"Skeleton Tower Bolts size (mm)"	NA

**Additional Specification Parameters - Tower Bolts (Ferrous Metals) As Per IS 204 ( 40 pieces )**

Specification Parameter Name	Bid Requirement (Allowed Values)
as per requirement :CROWN /LOTUS /GODREJ	as per requirement :CROWN /LOTUS /GODREJ

\* Bidders offering must also comply with the additional specification parameters mentioned above.

**परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity**

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****MUMBAI	40	60

**Tower Bolts (Ferrous Metals) As Per IS 204 ( 70 pieces )**

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

**तकनीकी विशिष्टियाँ /Technical Specifications**

[\\* जेम कैटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
ITEM	Item	"Barrel Tower Bolts (Type - 1B)"
SPECIFICATION	Conforming to Specification - no IS: 204 (Part 1), latest	Yes
FILTER	Shape of the Bolt	Half Round
	Fixing of knob with Bolt	Screwed
	Bolt's Finish	Stain Finished
	Other Part of Tower Bolt Finish	Stain Finished
DIMENSIONS	"Barrel Tower Bolts size (mm)"	75
	Semi-Barrel Tower Bolts size (mm)	75
	Riveted or Spot Welded Tower Bolts size (mm)	200
	"Skeleton Tower Bolts size (mm)"	450

**Additional Specification Parameters - Tower Bolts (Ferrous Metals) As Per IS 204 ( 70 pieces )**

Specification Parameter Name	Bid Requirement (Allowed Values)
as per requirement :CROWN /LOTUS /GODREJ	as per requirement :CROWN /LOTUS /GODREJ

\* Bidders offering must also comply with the additional specification parameters mentioned above.

**परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity**

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****MUMBAI	70	60

**Tower Bolts (Ferrous Metals) As Per IS 204 ( 70 pieces )**

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

**तकनीकी विशिष्टियाँ /Technical Specifications**

[\\* जेम कैटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
ITEM	Item	"Barrel Tower Bolts (Type - 1B)"
SPECIFICATION	Conforming to Specification - no IS: 204 (Part 1), latest	Yes
FILTER	Shape of the Bolt	Half Round
	Fixing of knob with Bolt	Screwed
	Bolt's Finish	Stain Finished
	Other Part of Tower Bolt Finish	Stain Finished
DIMENSIONS	"Barrel Tower Bolts size (mm)"	200
	Semi-Barrel Tower Bolts size (mm)	200
	Riveted or Spot Welded Tower Bolts size (mm)	200
	"Skeleton Tower Bolts size (mm)"	450

**Additional Specification Parameters - Tower Bolts (Ferrous Metals) As Per IS 204 ( 70 pieces )**

Specification Parameter Name	Bid Requirement (Allowed Values)
as per requirement :CROWN /LOTUS /GODREJ	as per requirement :CROWN /LOTUS /GODREJ

\* Bidders offering must also comply with the additional specification parameters mentioned above.

**परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity**

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****MUMBAI	70	60

**Plastics Bib Taps Pillar Taps Angle Valves And Stop Valves As Per IS 9763:2000 (Latest) ( 65 pieces )**

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

**तकनीकी विशिष्टियाँ /Technical Specifications**

[\\* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
Ungrouped	Type of Tap/ Valve	Pillar Tap
	Materials used for the manufacture body of Tap/ Valve	Polytetra Methylene Terephthalate (PTMT)
	Nominal Sizes of Plastic taps and stop valves	15 mm (1/2 &quot;)
	Finish for Taps/ valves	Gold Plating
	Threading of Taps/ Valve	Internal
	Minimum Thickness in any portion of the body and bonnet for all sizes (mm)	2.5

**Additional Specification Parameters - Plastics Bib Taps Pillar Taps Angle Valves And Stop Valves As Per IS 9763:2000 (Latest) ( 65 pieces )**

Specification Parameter Name	Bid Requirement (Allowed Values)
as per requirement :PRAYAG /POLYTUF/ PRIMA	as per requirement :PRAYAG /POLYTUF/ PRIMA

\* Bidders offering must also comply with the additional specification parameters mentioned above.

**परिषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity**

क्र.सं./S.No.	परिषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****MUMBAI	65	60

**Connection Pipe With Nuts (V2) ( 45 pieces )**

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

**तकनीकी विशिष्टियाँ /Technical Specifications**

[\\* जेम कैटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
Generic	Washer Provided	Yes
Material	Connection Pipe Material	PVC Metal Braided Pipe

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
	Connection Nut Material	Brass Or higher
	Washer Material	Silicon Or higher
Dimensions	Connection Thread Size(in mm)	15
	Length of Connection Pipe(in mm)	600
	Pressure Rating(kg/cm <sup>2</sup> )	1, 2, 3, 4, 5, 6 Or higher
	Diameter of Pipe (in mm)	15
TEST REPORT	Availability of Test Report from Central Govt /NABL/ILAC accredited lab to prove conformity to specification	Yes

#### Additional Specification Parameters - Connection Pipe With Nuts (V2) ( 45 pieces )

Specification Parameter Name	Bid Requirement (Allowed Values)
as per requirement :PRAYAG /POLYTUF/ PRIMA	as per requirement :PRAYAG /POLYTUF/ PRIMA

\* Bidders offering must also comply with the additional specification parameters mentioned above.

#### परिषेती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परिषेती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****MUMBAI	45	60

#### Waste Pipe ( 50 pieces )

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

#### तकनीकी विशिष्टियाँ /Technical Specifications

[\\* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
Item	Type of Waste Pipe	Flexible
Material	Material of Pipe	PVC



विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
Dimension	Material of Waste Coupling attached with Pipe	PVC
	Basin Connection Size (in mm)	50
	Length of Pipe(in mm)	750
	Pipe Outer Diameter(in mm)	40
	Pipe Wall Thickness(in mm)	1.0

#### Additional Specification Parameters - Waste Pipe ( 50 pieces )

Specification Parameter Name	Bid Requirement (Allowed Values)
as per requirement :PRAYAG /POLYTUF/ PRIMA	as per requirement :PRAYAG /POLYTUF/ PRIMA

\* Bidders offering must also comply with the additional specification parameters mentioned above.

#### परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****MUMBAI	50	60

#### Flushing Cistern ( 30 pieces )

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

#### तकनीकी विशिष्टियाँ /Technical Specifications

[\\* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	Operating Mechanism	Push Button Type
	Flushing Operation	Dual Flush System
	CAPACITY OF THE CISTERN IN LITRES	10 LTR
	Flush Pipe	With

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
MATERIAL	Material of Flush Pipe	PP
	Material of Cistern	Acrylonitrile-Butadiene-Styrene (ABS)
WARANTEE	WARANTEE PERIOD IN NUMBER OF YEARS	3

#### Additional Specification Parameters - Flushing Cistern ( 30 pieces )

Specification Parameter Name	Bid Requirement (Allowed Values)
as per requirement :PRAYAG /POLYTUF/ PRIMA	as per requirement :PRAYAG /POLYTUF/ PRIMA

\* Bidders offering must also comply with the additional specification parameters mentioned above.

#### परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****MUMBAI	30	60

#### HYDRAULICALLY REGULATED DOOR CLOSERS ( 10 pieces )

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

#### तकनीकी विशिष्टियाँ /Technical Specifications

[\\* जेम कैटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	Types of door closers	Bottle type (Type A) - As per Fig. 1 and 2 of governing specification
	Nominal sizes of door closers	Designation of closer: 1 - for light doors such as double leaved and toilet doors (Mass of door up to 35 Kgs and width of door up to 700 mm)
	Scope of supply	Knocked Down to be Assembled at Consignee Site by the Seller
	Type of Closer (based on direction of the opening of door)	Right Closer (for Anti-clock wise door)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
	<b>Closing time of regulating screw</b>	5 Secs
MATERIAL FOR COMONENT PARTS	<b>Non-porous body and back plate</b>	Cast iron confmg. to IS 210 : latest
	<b>Torsion spring helcal spring</b>	Steel confmg. to IS 4454 (PART 2) : latest
	<b>Nuts</b>	Steel confmg. to IS 7283 : latest
	<b>Piston or Rack-piston/pinion</b>	Steel aluminium alloy confmg. to IS 7283 : latest
	<b>Packing / Washers</b>	Cork sheet confmg. to IS 4253 (Part 1) : latest
	<b>Control valve screw</b>	Bronze confmg. to IS 28 : latest
	<b>Adjusting Arm</b>	Steel confmg. to IS 7283 : latest
	<b>Main Arm</b>	Aluminium alloy confmg. to IS 617 : latest
	<b>Clamp</b>	Steel confmg. to IS 7283 : latest
	<b>Concentric ratcher (For bottle type)</b>	Steel confmg. to IS 7283 : latest
	<b>Internal bearing and gland</b>	Brass confmg. to IS 292 : latest
	<b>Pawl</b>	Steel confmg. to IS 7283 : latest
	<b>Top lid</b>	Aluminium alloy sheet confmg. to IS 737 : latest
FINISHING	<b>Finish of door closer</b>	Be painted and finished with lacquer in colours
WARRANTY	<b>Warranty period</b>	1 – Year
CERTIFICATION	<b>ISI Mark</b>	Yes
	<b>Test reports in respect of to be furnished to buyer's on demand</b>	No
	<b>OEM of offered product is ISO 9001:2015 certified</b>	Yes
	<b>OEM of offered product is ISO 14001:2015 certified</b>	No
	<b>OEM of offered product is ISO 18001:2007 certified</b>	No

**Additional Specification Parameters - HYDRAULICALLY REGULATED DOOR CLOSERS ( 10 pieces )**

Specification Parameter Name	Bid Requirement (Allowed Values)
as per requirement :CROWN/ LOTUS/ GODREJ	as per requirement :CROWN/ LOTUS/ GODREJ

\* Bidders offering must also comply with the additional specification parameters mentioned above.

## अतिरिक्त विशिष्टि दस्तावेज़ /Additional Specification Documents

Applicable Specification Document	<a href="#">View</a>
-----------------------------------	----------------------

## परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****MUMBAI	10	60

## Plastics Bib Taps Pillar Taps Angle Valves And Stop Valves As Per IS 9763:2000 (Latest) ( 63 pieces )

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

## तकनीकी विशिष्टियाँ /Technical Specifications

[\\* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
Ungrouped	Type of Tap/ Valve	Bib Tap
	Materials used for the manufacture body of Tap/ Valve	Polytetra Methylene Terephthalate (PTMT)
	Nominal Sizes of Plastic taps and stop valves	15 mm (1/2 ")
	Finish for Taps/ valves	Gold Plating
	Threading of Taps/ Valve	External
	Minimum Thickness in any portion of the body and bonnet for all sizes (mm)	2.5

## Additional Specification Parameters - Plastics Bib Taps Pillar Taps Angle Valves And Stop Valves As Per IS 9763:2000 (Latest) ( 63 pieces )

Specification Parameter Name	Bid Requirement (Allowed Values)
as per requirement :PRAYAG /POLYTUF/ PRIMA	as per requirement :PRAYAG /POLYTUF/ PRIMA

\* Bidders offering must also comply with the additional specification parameters mentioned above.

**परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity**

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****MUMBAI	63	60

**Toilet Seat Covers (V2) ( 25 pieces )**

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

**तकनीकी विशिष्टियाँ /Technical Specifications**

\* जेम कैटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
Physical Characteristics	<b>Material of cover</b>	Plastic
Dimensions	<b>Length of cover(in cm)</b>	31-40
	<b>Width of cover(in cm)</b>	36-40
	<b>Warranty</b>	2, 3 Or higher
Test Report	<b>Availability of Test Report from Central Govt/NABL/ILAC accredited lab to prove conformity to specification</b>	No
	<b>Test Report to be furnished to the buyer on demand</b>	No

**Additional Specification Parameters - Toilet Seat Covers (V2) ( 25 pieces )**

Specification Parameter Name	Bid Requirement (Allowed Values)
as per requirement :PRAYAG /POLYTUF/ PRIMA	as per requirement :PRAYAG /POLYTUF/ PRIMA

\* Bidders offering must also comply with the additional specification parameters mentioned above.

**परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity**

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****MUMBAI	25	60

### Curtain Pipe, Sider And Mounting Bracket ( 70 meter )

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

#### तकनीकी विशिष्टियाँ /Technical Specifications

[\\* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
ITEM	ITEM	Curtain Pipe
OTHER REQUIREMENTS	Sider(one pair per pipe)	Without
DIMENSON	Outside Diameter of curtain pipe (in mm)	19mm
	Length of curtain pipe( In Meter)	5
	Minimum Wall thickness of pipe ( In MM)	1, 2, 3, 4, 5 Or higher
	Minimum thickness of Curtain pipe hanging bracket (in mm)	2, 3 Or higher

### Additional Specification Parameters - Curtain Pipe, Sider And Mounting Bracket ( 70 meter )

Specification Parameter Name	Bid Requirement (Allowed Values)
as per requirement : PRAYAG/ PRIMA/ CORONET	as per requirement : PRAYAG/ PRIMA/ CORONET

\* Bidders offering must also comply with the additional specification parameters mentioned above.

#### परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****MUMBAI	70	60

**Tower Bolts (Ferrous Metals) As Per IS 204 ( 34 pieces )**

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

**तकनीकी विशिष्टियाँ /Technical Specifications**

\* जेम कैटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
ITEM	Item	"Riveted or Spot Welded Tower Bolts (Type - 4A)"
SPECIFICATION	Conforming to Specification - no IS: 204 (Part 1), latest	Yes
FILTER	Shape of the Bolt	"Robust construction (as per buyer requirements)"
	Fixing of knob with Bolt	Riveted
	Bolt's Finish	"Copper oxide (Copper Oxidized as per IS 1376 : 1987)"
	Other Part of Tower Bolt Finish	"Copper oxide (Copper Oxidized as per IS 1376 : 1987)"
DIMENSIONS	"Barrel Tower Bolts size (mm)"	300
	Semi-Barrel Tower Bolts size (mm)	NA
	Riveted or Spot Welded Tower Bolts size (mm)	NA
	"Skeleton Tower Bolts size (mm)"	NA

**Additional Specification Parameters - Tower Bolts (Ferrous Metals) As Per IS 204 ( 34 pieces )**

Specification Parameter Name	Bid Requirement (Allowed Values)
as per requirement : CROWN/ LOTUS/ GODREJ	as per requirement : CROWN/ LOTUS/ GODREJ

\* Bidders offering must also comply with the additional specification parameters mentioned above.

**परिषेती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity**

क्र.सं./S.N o.	परिषेती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****MUMBAI	34	60

**Metal Alloy Casting Water Tap With Aerator (V2) ( 10 pieces )**

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

**तकनीकी विशिष्टियाँ /Technical Specifications**

[\\* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
ITEM	Tap Mounting Type	Wall Mount tap
Material	Material	Brass
Description	Type of Faucet	Quarter Turn
	Aerator Material	Plastic
Dimension	Nominal Thread Size of Tap (mm)	15

**Additional Specification Parameters - Metal Alloy Casting Water Tap With Aerator (V2) ( 10 pieces )**

Specification Parameter Name	Bid Requirement (Allowed Values)
as per requirement :PRAYAG /PRIMA /CORONET	as per requirement :PRAYAG /PRIMA /CORONET

\* Bidders offering must also comply with the additional specification parameters mentioned above.

**प्रेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity**

क्र.सं./S.N o.	प्रेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****MUMBAI	10	60

**Metal Alloy Casting Water Tap With Aerator (V2) ( 40 pieces )**

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

**तकनीकी विशिष्टियाँ /Technical Specifications**

[\\* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
ITEM	Tap Mounting Type	Bib tap



विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
Material	Material	Brass
Description	Type of Faucet	Multi Turn
	Aerator Material	Metal
Dimension	Nominal Thread Size of Tap (mm)	15

#### Additional Specification Parameters - Metal Alloy Casting Water Tap With Aerator (V2) ( 40 pieces )

Specification Parameter Name	Bid Requirement (Allowed Values)
as per requirement :PRAYAG /PRIMA /CORONET	as per requirement :PRAYAG /PRIMA /CORONET

\* Bidders offering must also comply with the additional specification parameters mentioned above.

#### परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****MUMBAI	40	60

#### Metal Alloy Casting Water Tap With Aerator (V2) ( 15 pieces )

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

#### तकनीकी विशिष्टियाँ /Technical Specifications

[\\* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
ITEM	Tap Mounting Type	Bib tap
Material	Material	Brass
Description	Type of Faucet	Multi Turn
	Aerator Material	Metal
Dimension	Nominal Thread Size of Tap (mm)	15

**Additional Specification Parameters - Metal Alloy Casting Water Tap With Aerator (V2) ( 15 pieces )**

Specification Parameter Name	Bid Requirement (Allowed Values)
as per requirement :PRAYAG /PRIMA /CORONET	as per requirement :PRAYAG /PRIMA /CORONET

\* Bidders offering must also comply with the additional specification parameters mentioned above.

**परिषी/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity**

क्र.सं./S.N o.	परिषी/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****MUMBAI	15	60

**Metal Alloy Casting Water Tap With Aerator (V2) ( 10 pieces )**

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

**तकनीकी विशिष्टियाँ /Technical Specifications**

[\\* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
ITEM	Tap Mounting Type	Pillar tap
Material	Material	Brass
Description	Type of Faucet	Quarter Turn
	Aerator Material	Metal
Dimension	Nominal Thread Size of Tap (mm)	15

**Additional Specification Parameters - Metal Alloy Casting Water Tap With Aerator (V2) ( 10 pieces )**

Specification Parameter Name	Bid Requirement (Allowed Values)
as per requirement :PRAYAG /PRIMA /CORONET	as per requirement :PRAYAG /PRIMA /CORONET

\* Bidders offering must also comply with the additional specification parameters mentioned above.

**परिषी/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity**

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****MUMBAI	10	60

### Metal Alloy Casting Water Tap With Aerator (V2) ( 20 pieces )

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

#### तकनीकी विशिष्टियाँ /Technical Specifications

[\\* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
ITEM	Tap Mounting Type	Pillar tap
Material	Material	Brass
Description	Type of Faucet	Hand-held
	Aerator Material	Metal
Dimension	Nominal Thread Size of Tap (mm)	15

### Additional Specification Parameters - Metal Alloy Casting Water Tap With Aerator (V2) ( 20 pieces )

Specification Parameter Name	Bid Requirement (Allowed Values)
as per requirement :PRAYAG /PRIMA /CORONET	as per requirement :PRAYAG /PRIMA /CORONET

\* Bidders offering must also comply with the additional specification parameters mentioned above.

#### परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****MUMBAI	20	60

### HYDRAULICALLY REGULATED DOOR CLOSERS ( 60 pieces )

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

#### तकनीकी विशिष्टियाँ /Technical Specifications

\* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	<b>Types of door closers</b>	Tubular type (Type B)- As per Fig. 3 and 4 of governing specification
	<b>Nominal sizes of door closers</b>	Designation of closer: 2 - for interior door such as of bed room, kitchen and store (Mass of door 36 to 60 Kgs and width of door 701 to 850 mm)
	<b>Scope of supply</b>	Assembled Ready to Use
	<b>Type of Closer (based on direction of the opening of door)</b>	Left Closer (for Clock wise Door)
	<b>Closing time of regulating screw</b>	5 Secs
MATERIAL FOR COMONENT PARTS	<b>Non-porous body and back plate</b>	Cast iron confmg. to IS 210 : latest
	<b>Torsion spring helcal spring</b>	Steel confmg. to IS 2507 : latest
	<b>Nuts</b>	Steel confmg. to IS 7283 : latest
	<b>Piston or Rack-piston/pinion</b>	Steel aluminium alloy confmg. to IS 7283 : latest
	<b>Packing / Washers</b>	Cork sheet confmg. to IS 4253 (Part 1) : latest
	<b>Control valve screw</b>	Steel confmg. to Grade A of IS 2062 : latest
	<b>Adjusting Arm</b>	Steel confmg. to IS 7283 : latest
	<b>Main Arm</b>	Steel confmg. to IS 7283 : latest
	<b>Clamp</b>	Steel confmg. to IS 7283 : latest
	<b>Concentric ratchet (For bottle type)</b>	Steel confmg. to IS 7283 : latest
	<b>Internal bearing and gland</b>	Steel confmg. to IS 7283 : latest
	<b>Pawl</b>	Steel confmg. to IS 7283 : latest
	<b>Top lid</b>	Steel sheet confmg. to IS 513 : latest
FINISHING	<b>Finish of door closer</b>	Be painted and finished with lacquer in colours
WARRANTY	<b>Warranty period</b>	1 - Year
CERTIFICATION	<b>ISI Mark</b>	No
	<b>Test reports in respect of to be furnished to buyer's on demand</b>	No
	<b>OEM of offered product is ISO 9001:2015 certified</b>	No
	<b>OEM of offered product is ISO 14001:2015 certified</b>	No
	<b>OEM of offered product is ISO 18001:2007 certified</b>	No

**Additional Specification Parameters - HYDRAULICALLY REGULATED DOOR CLOSERS ( 60 pieces )**

Specification Parameter Name	Bid Requirement (Allowed Values)
As per requirement : CROWN LOTUS GODREJ	As per requirement : CROWN LOTUS GODREJ

\* Bidders offering must also comply with the additional specification parameters mentioned above.

**अतिरिक्त विशिष्टि दस्तावेज़ /Additional Specification Documents**

Applicable Specification Document	<a href="#">View</a>
-----------------------------------	----------------------

**परिषेती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity**

क्र.सं./S.No.	परिषेती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****MUMBAI	60	60

**Waste Fittings For Washbasin And Sinks As Per IS 2963 ( 40 pieces )**

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

**तकनीकी विशिष्टियाँ /Technical Specifications**

[\\* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
RAW MATERIAL	Material of Waste Fitting	Leaded Tin Bronze conforming to Grade 2 of IS 318/1962
DIMENSION	Nominal Size	32 mm for washbasin
WARANTEE	WARANTEE PERIOD IN NUMBER OF YEARS	5

**Additional Specification Parameters - Waste Fittings For Washbasin And Sinks As Per IS 2963 ( 40 pieces )**

Specification Parameter Name	Bid Requirement (Allowed Values)
as per requirement :PRAYAG /PRIMA /CORONET	as per requirement :PRAYAG /PRIMA /CORONET

\* Bidders offering must also comply with the additional specification parameters mentioned above.

**परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity**

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****MUMBAI	40	60

**M - Seal As Per IS 9197 ( 30 pieces )**

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

**तकनीकी विशिष्टियाँ /Technical Specifications**

[\\* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
Certifications & Standards	BIS Certification	No
	Conformity IS 9197 - 1979	Yes
Packaging	Packaging Size	0.1, 0.25 (kilogram)

**परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity**

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****MUMBAI	30	60

**Cast Copper Alloy Screw Down Bib Taps And Stop Valves For Water Services As Per IS 781 ( 15 pieces )**

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

**तकनीकी विशिष्टियाँ /Technical Specifications**

[\\* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
Ungrouped	Item	Stop Valve (Externally Threaded)
	Material of body and Bonnet	Cast Brass
	Nominal Size (mm)	15
	Finish	Cast Finish
	Material of Gland,Crutch (handle), Washer Plate	Leaded Tin, Bronze
	Shape of Shoulder at the Bonnet	Hexagonal
	ISI marked	Yes

**Additional Specification Parameters - Cast Copper Alloy Screw Down Bib Taps And Stop Valves For Water Services As Per IS 781 ( 15 pieces )**

Specification Parameter Name	Bid Requirement (Allowed Values)
as per requirement :PRAYAG /PRIMA /CORONET	as per requirement :PRAYAG /PRIMA /CORONET

\* Bidders offering must also comply with the additional specification parameters mentioned above.

**परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity**

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****MUMBAI	15	60

**Cast Copper Alloy Screw Down Bib Taps And Stop Valves For Water Services As Per IS 781 ( 20 pieces )**

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

**तकनीकी विशिष्टियाँ /Technical Specifications**

[\\* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
Ungrouped	Item	Stop Valve (Mixed End)
	Material of body and Bonnet	Cast Brass

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
	Nominal Size (mm)	15
	Finish	Nickel-Chromium plated with coating thickness Not less than Service Condition Number 2 of table 3 of IS 1068/1993
	Material of Gland, Crutch (handle), Washer Plate	Brass (Extruded, Rolled, Cast, die cast)
	Shape of Shoulder at the Bonnet	Hexagonal
	ISI marked	Yes

**Additional Specification Parameters - Cast Copper Alloy Screw Down Bib Taps And Stop Valves For Water Services As Per IS 781 ( 20 pieces )**

Specification Parameter Name	Bid Requirement (Allowed Values)
as per requirement :PRAYAG /PRIMA /CORONET	as per requirement :PRAYAG /PRIMA /CORONET

\* Bidders offering must also comply with the additional specification parameters mentioned above.

**परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity**

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****MUMBAI	20	60

**European Pattern Toilet Seat Vitreous China ( 10 pieces )**

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

**तकनीकी विशिष्टियाँ /Technical Specifications**

[\\* जेम कैटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	Pattern as per IS 2556 part 2	Pattern 1 with S-Trap
	Flushing Rim Type	Box Rim Type



**Additional Specification Parameters - European Pattern Toilet Seat Vitreous China ( 10 pieces )**

Specification Parameter Name	Bid Requirement (Allowed Values)
as per requirement :PRAYAG /PRIMA /CORONET	as per requirement :PRAYAG /PRIMA /CORONET

\* Bidders offering must also comply with the additional specification parameters mentioned above.

**परिषीती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity**

क्र.सं./S.N o.	परिषीती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****MUMBAI	10	60

**Connection Pipe With Nuts (V2) ( 60 pieces )**

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

**तकनीकी विशिष्टियाँ /Technical Specifications**

[\\* जेम कैटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
Generic	Washer Provided	Yes
Material	Connection Pipe Material	PVC Metal Braided Pipe
	Connection Nut Material	Brass Or higher
	Washer Material	Silicon Or higher
Dimensions	Connection Thread Size(in mm)	15
	Length of Connection Pipe(in mm)	450
	Pressure Rating(kg/cm <sup>2</sup> )	1, 2 Or higher
	Diameter of Pipe (in mm)	15
TEST REPORT	Availability of Test Report from Central Govt /NABL/ILAC accredited lab to prove conformity to specification	Yes

**Additional Specification Parameters - Connection Pipe With Nuts (V2) ( 60 pieces )**

Specification Parameter Name	Bid Requirement (Allowed Values)
as per requirement :PRAYAG /PRIMA /CORONET	as per requirement :PRAYAG /PRIMA /CORONET

\* Bidders offering must also comply with the additional specification parameters mentioned above.

**परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity**

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****MUMBAI	60	60

**Sinks / Wash Basins - Vitreous China As Per IS 2556 (Part 4) ( 10 pieces )**

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

**तकनीकी विशिष्टियाँ /Technical Specifications**

[\\* जेम कैटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	<b>Conformity to Indian Standard</b>	IS: 2556 (Part - 4) Latest
	<b>Pattern</b>	Flat Back
CONSTRUCTION	<b>Overall length (cm) (±10)</b>	60
	<b>Overall Breadth (cm) (±10)</b>	40
	<b>Overall Height (cm) (±10)</b>	40
	<b>Bottle Trap</b>	Without
	<b>Shape</b>	Semi Circle
	<b>Height of the Pedstal (cm) (±10)</b>	No Pedestal
PERFORMANCE	<b>Fixing Arrangement</b>	Wall Hung
WARANTEE	<b>WARANTEE PERIOD IN NUMBER OF YEARS</b>	1

**Additional Specification Parameters - Sinks / Wash Basins - Vitreous China As Per IS 2556 (Part 4) ( 10 pieces )**

Specification Parameter Name	Bid Requirement (Allowed Values)
as per requirement :PRAYAG /PRIMA /CORONET	as per requirement :PRAYAG /PRIMA /CORONET

\* Bidders offering must also comply with the additional specification parameters mentioned above.

**प्रेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity**

क्र.सं./S.No.	प्रेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****MUMBAI	10	60

**Cast Copper Alloy Screw Down Bib Taps And Stop Valves For Water Services As Per IS 781 ( 30 pieces )**

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

**तकनीकी विशिष्टियाँ /Technical Specifications**

\* जेम कैटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
Ungrouped	Item	Stop Valve (Externally Threaded)
	Material of body and Bonnet	Leaded in Tin Bronze
	Nominal Size (mm)	20
	Finish	Nickel-Chromium plated with coating thickness Not less than Service Condition Number 2 of table 3 of IS 1068/1993
	Material of Gland,Crutch (handle), Washer Plate	Leaded Tin, Bronze
	Shape of Shoulder at the Bonnet	Hexagonal
	ISI marked	Yes

**Additional Specification Parameters - Cast Copper Alloy Screw Down Bib Taps And Stop Valves For Water Services As Per IS 781 ( 30 pieces )**

Specification Parameter Name	Bid Requirement (Allowed Values)
as per requirement :PRAYAG /PRIMA /CORONET	as per requirement :PRAYAG /PRIMA /CORONET

\* Bidders offering must also comply with the additional specification parameters mentioned above.

**परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity**

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****MUMBAI	30	60

**Piano Type Modular Domestic Fan Regulator As Per IS 11037 ( 50 pieces )**

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

**तकनीकी विशिष्टियाँ /Technical Specifications**

\* जेम कैटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
Generic	Type of Regulator	Switch size
	No of steps	5
	BIS Marking	No
	Rated voltage	230.0 (Volt)
Construction	Color of regulator body	White
Certification & standards	Test report to be submitted to the Buyer on Demand	Yes

**Additional Specification Parameters - Piano Type Modular Domestic Fan Regulator As Per IS 11037 ( 50 pieces )**

Specification Parameter Name	Bid Requirement (Allowed Values)
as per requirement : ANCHOR/ WIPRO/ ADHUNIK /LEGRAND	as per requirement : ANCHOR/ WIPRO/ ADHUNIK /LEGRAND

\* Bidders offering must also comply with the additional specification parameters mentioned above.

**परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity**

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****MUMBAI	50	100

**Piano Type Non Modular Electrical Switch Socket Combination As Per IS 3854 And IS 1293 ( 100 pieces )**

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

Bis Required	Yes
--------------	-----

**तकनीकी विशिष्टियाँ /Technical Specifications**

[\\* जेम कैटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
Generic	Rated current	6A
	Rated voltage	240.0 (Volt)
	Combination with Junction Box	With Box
Construction	According to type of terminal	Screw type terminal
	Current carrying material	Copper
	Color of switch body	White
Certification & standards	Warranty	2.0 (year)

**Additional Specification Parameters - Piano Type Non Modular Electrical Switch Socket Combination As Per IS 3854 And IS 1293 ( 100 pieces )**

Specification Parameter Name	Bid Requirement (Allowed Values)
as per requirement : ANCHOR/ WIPRO/ ADHUNIK /LEGRAND	as per requirement : ANCHOR/ WIPRO/ ADHUNIK /LEGRAND

\* Bidders offering must also comply with the additional specification parameters mentioned above.

**परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity**

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****MUMBAI	100	60

**Modular Piano Type Domestic Electrical Switches As Per IS 3854 ( 200 pieces )**

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

Bis Required	Yes
--------------	-----

#### तकनीकी विशिष्टियाँ /Technical Specifications

\* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
Generic	Type of Switch	1 way switch
	Rated current	6A
	Rated voltage	240.0 (Volt)
Switch classification	No. of poles	Single pole
	According to type of terminal	Screwless type terminal
	No. of modules	1 module
Construction	Current carrying material	Brass
	Color of switch body	white
Certification & standards	Warranty	1.0 (year)

#### Additional Specification Parameters - Modular Piano Type Domestic Electrical Switches As Per IS 3854 ( 200 pieces )

Specification Parameter Name	Bid Requirement (Allowed Values)
as per requirement : ANCHOR/ WIPRO/ ADHUNIK /LEGRAND	as per requirement : ANCHOR/ WIPRO/ ADHUNIK /LEGRAND

\* Bidders offering must also comply with the additional specification parameters mentioned above.

#### प्रेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	प्रेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****MUMBAI	200	60

#### XLPE Cable For Working Voltages Up To And Including 1.1 KV As Per IS 7098 (Part 1) ( 200 meter )

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

Bis Required	Yes
--------------	-----

## तकनीकी विशिष्टियाँ /Technical Specifications

\* जेम कैटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
STANDARDS	Conformity of the specification for XLPE cable	as per IS:7098 (Part 1): 1988 latest
	Cables suitable for use in mines	No
	Cables suitable for use in low temperature applications	Yes
GENERIC	Classification of cables for improved fire performance category	01
	Nominal Area of Conductor (in Sq mm)	10
	Number of core (in Nos)	2
CONSTRUCTION	Material of conductor	Plain Copper
	Type of inner sheath	Thermoplastic
ARMOURING	Type of cable	Armoured cable
	Material of armouring	Galvanized steel formed wire
	Type of armouring	Single strip
CERTIFICATION	Availability of Optional Test Reports	Cold bend test for outer sheath, Cold impact test for outer sheath, Resistance test for Armour, Not applicable

### Additional Specification Parameters - XLPE Cable For Working Voltages Up To And Including 1.1 KV As Per IS 7098 (Part 1) ( 200 meter )

Specification Parameter Name	Bid Requirement (Allowed Values)
as per requirement :GRANDLAY /PLAZA /LEGRAND	as per requirement :GRANDLAY /PLAZA /LEGRAND

\* Bidders offering must also comply with the additional specification parameters mentioned above.

### परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
---------------	---	-------------	------------------	------------------------------

क्र.सं./S.No.	प्रेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****MUMBAI	200	60

### XLPE Cable For Working Voltages Up To And Including 1.1 KV As Per IS 7098 (Part 1) ( 180 meter )

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

Bis Required	Yes
--------------	-----

### तकनीकी विशिष्टियाँ /Technical Specifications

[\\* जेम कैटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
STANDARDS	Conformity of the specification for XLPE cable	as per IS:7098 (Part 1): 1988 latest
	Cables suitable for use in mines	No
	Cables suitable for use in low temperature applications	No
GENERIC	Classification of cables for improved fire performance category	C2 - FR-LSH
	Nominal Area of Conductor (in Sq mm)	6
	Number of core (in Nos)	2
CONSTRUCTION	Material of conductor	Plain Copper
	Type of inner sheath	Thermoplastic
ARMOURING	Type of cable	Armoured cable
	Material of armouring	Galvanized steel formed wire
	Type of armouring	Single strip
CERTIFICATION	Availability of Optional Test Reports	Not applicable

**Additional Specification Parameters - XLPE Cable For Working Voltages Up To And Including 1.1 KV As Per IS 7098 (Part 1) ( 180 meter )**



Specification Parameter Name	Bid Requirement (Allowed Values)
as per requirement :GRANDLAY /PLAZA /LEGRAND	as per requirement :GRANDLAY /PLAZA /LEGRAND

\* Bidders offering must also comply with the additional specification parameters mentioned above.

#### प्रेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	प्रेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****MUMBAI	180	60

#### Special terms and conditions-Version:1 effective from 16-01-2025 for category M - Seal as per IS 9197

- The product may also carry an ISI Mark/Standard Mark as per the BIS standard governing this category. As such Buyers may also opt for ISI marked product while creating BID. In such cases buyer shall verify valid BIS License for the same at the time of evaluation of BID and check ISI marking at the time of receipt of material before issuing CRAC.

#### क्रेता द्वारा जोड़ी गई बिड की विशेष शर्तें/Buyer Added Bid Specific Terms and Conditions

##### 1. Generic

OPTION CLAUSE: The Purchaser reserves the right to increase or decrease the quantity to be ordered up to 25 percent of bid quantity at the time of placement of contract. The purchaser also reserves the right to increase the ordered quantity up to 25% of the contracted quantity during the currency of the contract at the contracted rates. The delivery period of quantity shall commence from the last date of original delivery order and in cases where option clause is exercised during the extended delivery period the additional time shall commence from the last date of extended delivery period. The additional delivery time shall be  $(\text{Increased quantity} \div \text{Original quantity}) \times \text{Original delivery period (in days)}$ , subject to minimum of 30 days. If the original delivery period is less than 30 days, the additional time equals the original delivery period. The Purchaser may extend this calculated delivery duration up to the original delivery period while exercising the option clause. Bidders must comply with these terms.

##### 2. Generic

**Bidder financial standing:** The bidder should not be under liquidation, court receivership or similar proceedings, should not be bankrupt. Bidder to upload undertaking to this effect with bid.

##### 3. Generic

Bidder shall submit the following documents along with their bid for Vendor Code Creation:

- Copy of PAN Card.
- Copy of GSTIN.
- Copy of Cancelled Cheque.
- Copy of EFT Mandate duly certified by Bank.

#### 4. **Buyer Added Bid Specific ATC**

Buyer Added text based ATC clauses

##### **ATC**

1. Bidder to provide technical data sheet for the items quoted in the bid makes specified in the bid will only be accepted as its for a predefined work past performance of prior supply work is a must.
2. Bidder must provide OEM authorization document with specific bid number.
3. Bidder must have prior experience of fixing contracts in MES.
4. Only category 1 makes under HQ Chief Engineer Southern command approved make documents to be upload in Bid.
5. Bidder must have local presence in the same city/ state for supply work.
6. The OEM must give guarantee letter of behalf of reseller.
7. Warranty certificate is mandatory.
8. Test certificate of items is must upload in bid.
9. Sample to be provided within bid duration before opening of Technical bid is mandatory and approved copy of sample to be uploaded.
10. Bidder financial standing: The bidder should not be under liquidation, court receivership or similar proceedings, should not be bankrupt. Bidder to upload undertaking to this effect with bid.
11. Bidders are advised to check applicable GST on their own before quoting . Buyer will not take any responsibility in this regards.
12. Bidder shall submit the following documents along with their bid for Vendor Code Creation: a. Copy of PAN Card. b. Copy of GSTIN. c. Copy of Cancelled Cheque. Copy of NEFT Mandate duly certified by Bank.
13. NON DISCLOSURE DECLARATION CERTIFICATE (On Bidder Letter Head) to be uploaded with bid:
14. I M/s. NAME OF BIDDER hereby declare that I shall not disclose the contract or any provision, specification, plan, design, pattern, sample or information thereof to any third party during and after expiry of Contract. 2. If denying the norms as per the Contract a legal action may be taken against me as per the existing Rules.
15. While generating invoice in GeM portal, the seller must upload scanned copy of GST invoice and the screenshot of GST portal confirming payment of GST.
16. Bidder's offer is liable to be rejected if they don't upload any of the Certificates/documents sought in the Bid document. ATC and Corrigendum if any.
17. EMD amount to be given in favor of CWE (Subs) Mumbai.

18. Upload annual turn over of OEM and also of bidder for 03 latest consecutive financial years for all mentioned makes to be quoted in this bid so as to get checked the genuineness of items supplied.

19. Required OEM Turnover and OEM Authorizations for All the branded item which will be quoted and One OEM Authorization bid No should be mentioned and Technical specification on OEM letter head.

20. Samples to be provided within bid duration before one day prior of opening of Technical bid is mandatory.

21. Only branded items to be provided.

22. Required technical specification on OEM letter head.

23. Required NABL certificate, BIS License and warranty certificate is mandatory.

24. Upload MII certificate only from OEM's of makes quoted out of the makes mentioned.

25. Makes of items will be accepted only given in Bid.

26. In case the documents are found to be fraud the bidder shall be blacklisted permanently.

27. The Bidder/Vendor must have to upload price list along with picture/image of all the items of this bid.

## अस्वीकरण/Disclaimer

The additional terms and conditions have been incorporated by the Buyer after approval of the Competent Authority in Buyer Organization, whereby Buyer organization is solely responsible for the impact of these clauses on the bidding process, its outcome, and consequences thereof including any eccentricity / restriction arising in the bidding process due to these ATCs and due to modification of technical specifications and / or terms and conditions governing the bid. If any clause(s) is / are incorporated by the Buyer regarding following, the bid and resultant contracts shall be treated as null and void and such bids may be cancelled by GeM at any stage of bidding process without any notice:-

1. Definition of Class I and Class II suppliers in the bid not in line with the extant Order / Office Memorandum issued by DPIIT in this regard.
2. Seeking EMD submission from bidder(s), including via Additional Terms & Conditions, in contravention to exemption provided to such sellers under GeM GTC.
3. Publishing Custom / BOQ bids for items for which regular GeM categories are available without any Category item bunched with it.
4. Creating BoQ bid for single item.
5. Mentioning specific Brand or Make or Model or Manufacturer or Dealer name.
6. Mandating submission of documents in physical form as a pre-requisite to qualify bidders.
7. Floating / creation of work contracts as Custom Bids in Services.
8. Seeking sample with bid or approval of samples during bid evaluation process. (However, in bids for [attached categories](#), trials are allowed as per approved procurement policy of the buyer nodal Ministries)
9. Mandating foreign / international certifications even in case of existence of Indian Standards without

specifying equivalent Indian Certification / standards.

10. Seeking experience from specific organization / department / institute only or from foreign / export experience.
11. Creating bid for items from irrelevant categories.
12. Incorporating any clause against the MSME policy and Preference to Make in India Policy.
13. Reference of conditions published on any external site or reference to external documents/clauses.
14. Asking for any Tender fee / Bid Participation fee / Auction fee in case of Bids / Forward Auction, as the case may be.
15. Buyer added ATC Clauses which are in contravention of clauses defined by buyer in system generated bid template as indicated above in the Bid Details section, EMD Detail, ePBG Detail and MII and MSE Purchase Preference sections of the bid, unless otherwise allowed by GeM GTC.
16. In a category based bid, adding additional items, through buyer added additional scope of work/ additional terms and conditions/or any other document. If buyer needs more items along with the main item, the same must be added through bunching category based items or by bunching custom catalogs or bunching a BoQ with the main category based item, the same must not be done through ATC or Scope of Work.

Further, if any seller has any objection/grievance against these additional clauses or otherwise on any aspect of this bid, they can raise their representation against the same by using the Representation window provided in the bid details field in Seller dashboard after logging in as a seller within 4 days of bid publication on GeM. Buyer is duty bound to reply to all such representations and would not be allowed to open bids if he fails to reply to such representations.

**All GeM Sellers / Service Providers are mandated to ensure compliance with all the applicable laws / acts / rules including but not limited to all Labour Laws such as The Minimum Wages Act, 1948, The Payment of Wages Act, 1936, The Payment of Bonus Act, 1965, The Equal Remuneration Act, 1976, The Payment of Gratuity Act, 1972 etc. Any non-compliance will be treated as breach of contract and Buyer may take suitable actions as per GeM Contract.**

[यह बिड सामान्य शर्तों के अंतर्गत भी शासित है /This Bid is also governed by the General Terms and Conditions](#)

जेम की सामान्य शर्तों के खंड 26 के संदर्भ में भारत के साथ भूमि सीमा साझा करने वाले देश के बिडर से खरीद पर प्रतिबंध के संबंध में भारत के साथ भूमि सीमा साझा करने वाले देश का कोई भी बिडर इस निविदा में बिड देने के लिए तभी पात्र होगा जब वह बिड देने वाला सक्षम प्राधिकारी के पास पंजीकृत हो। बिड में भाग लेते समय बिडर को इसका अनुपालन करना होगा और कोई भी गलत घोषणा किए जाने व इसका अनुपालन न करने पर अनुबंध को तत्काल समाप्त करने और कानून के अनुसार आगे की कानूनी कार्यवाई का आधार होगा।/In terms of GeM GTC clause 26 regarding Restrictions on procurement from a bidder of a country which shares a land border with India, any bidder from a country which shares a land border with India will be eligible to bid in this tender only if the bidder is registered with the Competent Authority. While participating in bid, Bidder has to undertake compliance of this and any false declaration and non-compliance of this would be a ground for immediate termination of the contract and further legal action in accordance with the laws.

**---धन्यवाद/Thank You---**