

बिड दस्तावेज़ / Bid Document

बिड विवरण / Bid Details	
बिड बंद होने की तारीख/समय / Bid End Date/Time	12-12-2025 15:00:00
बिड खुलने की तारीख/समय / Bid Opening Date/Time	12-12-2025 15:30:00
बिड पेशकश वैधता (बंद होने की तारीख से) / Bid Offer Validity (From End Date)	120 (Days)
मंत्रालय/राज्य का नाम / Ministry/State Name	Ministry Of Petroleum And Natural Gas
विभाग का नाम / Department Name	Indian Oil Corporation Limited
संगठन का नाम / Organisation Name	Indian Oil Corporation Limited
कार्यालय का नाम / Office Name	locl- Gujarat Refinery
कुल मात्रा / Total Quantity	42
वस्तु श्रेणी / Item Category	High Mast Lighting Tower for large area with LED Flood Lighting System (Q3) , LED Luminaire for Road and Street Lights (V2) Conforming to IS 10322 (Part 5 / Section 3) (Q3)
एमएसएमई के लिए अनुभव के वर्षों और टर्नओवर से छूट प्रदान की गई है / MSE Exemption for Years of Experience and Turnover	No
स्टार्टअप के लिए अनुभव के वर्षों और टर्नओवर से छूट प्रदान की गई है / Startup Exemption for Years of Experience and Turnover	No
विक्रेता से मांगे गए दस्तावेज़ / Document required from seller	Experience Criteria, Certificate (Requested in ATC), OEM Authorization Certificate, Additional Doc 1 (Requested in ATC), Additional Doc 2 (Requested in ATC) *In case any bidder is seeking exemption from Experience / Turnover Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer
क्या आप निविदाकारों द्वारा अपलोड किए गए दस्तावेज़ों को निविदा में भाग लेने वाले सभी निविदाकारों को दिखाना चाहते हैं? संदर्भ मेनू है / Do you want to show documents uploaded by bidders to all bidders participated in bid?	No
बिड लगाने की समय सीमा स्वतः नहीं बढ़ाने के लिए आवश्यक बिड की संख्या / Minimum number of bids required to disable automatic bid extension	3

बिड विवरण/Bid Details	
दिनों की संख्या, जिनके लिए बिड लगाने की समय-सीमा बढ़ाई जाएगी। / Number of days for which Bid would be auto-extended	7
ऑटो एक्सटेंशन अधिकतम कितनी बार किया जाना है। / Number of Auto Extension count	3
बिड से रिवर्स नीलामी सक्रिय किया/Bid to RA enabled	No
बिड का प्रकार/Type of Bid	Two Packet Bid
प्राथमिक उत्पाद श्रेणी/Primary product category	High Mast Lighting Tower for large area with LED Flood Lighting System
तकनीकी मूल्यांकन के दौरान तकनीकी स्पष्टीकरण हेतु अनुमत समय /Time allowed for Technical Clarifications during technical evaluation	5 Days
निरीक्षण आवश्यक (सूचीबद्ध निरीक्षण प्राधिकरण /जेम के साथ पूर्व पंजीकृत एजेंसियों द्वारा)/Inspection Required (By Empanelled Inspection Authority / Agencies pre-registered with GeM)	No
मूल्यांकन पद्धति/Evaluation Method	Total value wise evaluation
मध्यस्थता खंड/Arbitration Clause	Yes (Arbitration clause document) as per DoE OM No.F.1/2/2024-PPD dated 03.06.2024 Arbitration should not be routinely included in contracts
सुलह खंड/Mediation Clause	Yes (Mediation clause document) as per DoE OM No.F.1/2/2024-PPD dated 03.06.2024 mediation clause should not be routinely included in contracts and pre-litigation mediation can be taken up without any such clause also

ईएमडी विवरण/EMD Detail

आवश्यकता/Required	No
-------------------	----

ईपीबीजी विवरण /ePBG Detail

आवश्यकता/Required	No
-------------------	----

बोली विभाजन लागू नहीं किया गया/ Bid splitting not applied.

एमआईआई खरीद वरीयता/MII Purchase Preference

एमआईआई खरीद वरीयता/MII Purchase Preference	No
--	----

एमआईआई के लिए सक्षम प्राधिकारी का विवरण:/Details of the Competent Authority for MII

सक्षम प्राधिकारी का नाम/Name of Competent Authority	DGM MAT
सक्षम प्राधिकारी का पदनाम/Designation of Competent Authority	DGM MAT
सक्षम प्राधिकारी का कार्यालय/विभाग/प्रभाग/Office / Department / Division of Competent Authority	IOCL GUJARAT REFINERY
सीए अनुमोदन संख्या/CA Approval Number	9030M25F83
सक्षम प्राधिकारी अनुमोदन तिथि/Competent Authority Approval Date	28-11-2025
सक्षम प्राधिकारी द्वारा प्रदान की गई स्वीकृति का संक्षिप्त विवरण/Brief Description of the Approval Granted by Competent Authority	THIS HAS THE APPROVAL OF COMPETENT AUTHORITY .

Competent Authority Approval for not opting Make In India Preference : [View Document](#)

एमएसई खरीद वरीयता/MSE Purchase Preference

एमएसई खरीद वरीयता/MSE Purchase Preference	Yes
सूक्ष्म और लघु उद्यम मूल उपकरण निर्माताओं को खरीद में प्राथमिकता, यदि उनका मूल्य $L1+X\%$ तक की सीमा में हो / Purchase Preference to MSE OEMs available upto price within $L1+X\%$	15
सूक्ष्म और लघु उद्यम को खरीद में प्राथमिकता के लिए बिड की मात्रा का अधिकतम प्रतिशत / Maximum Percentage of Bid quantity for MSE purchase preference	100

1. Purchase preference will be given to MSEs having valid Udyam Registration and whose credentials are validated online through Udyam Registration portal as defined in Public Procurement Policy for Micro and Small Enterprises (MSEs) Order, 2012 dated 23.03.2012 issued by Ministry of Micro, Small and Medium Enterprises and its subsequent Orders/Notifications issued by concerned Ministry. If the bidder wants to avail themselves of the Purchase preference, the bidder must be the manufacturer / OEM of the offered product on GeM. Traders are excluded from the purview of Public Procurement Policy for Micro and Small Enterprises and hence resellers offering products manufactured by some other OEM are not eligible for any purchase preference. In respect of bid for Services, the bidder must be the Service provider of the offered Service. Relevant documentary evidence in this regard shall be uploaded along with the bid in respect of the offered product or service and Buyer will decide eligibility for purchase preference based on documentary evidence submitted, while evaluating the bid. If L-1 is not an MSE and MSE Seller (s) has / have quoted price within $L-1+ 15\%$ (Selected by Buyer) of margin of purchase preference /price band defined in relevant policy, such MSE Seller shall be given opportunity to match L-1 price and contract will be awarded for 100% (selected by Buyer) percentage of total quantity. The buyers are advised to refer the OM No. F.1/4/2021-PPD dated 18.05.2023 [OM_No.1_4_2021_PPD_dated_18.05.2023](#) for compliance of Concurrent application of Public Procurement Policy for Micro and Small Enterprises Order, 2012 and Public Procurement (Preference to Make in India) Order, 2017. Benefits of MSE will be allowed only if seller is validated on-line in GeM profile as well as validated and approved by Buyer after evaluation of documents submitted.

2. Estimated Bid Value indicated above is being declared solely for the purpose of guidance on EMD amount and for determining the Eligibility Criteria related to Turn Over, Past Performance and Project / Past Experience etc. This has no relevance or bearing on the price to be quoted by the bidders and is also not going to have any impact on bid participation. Also this is not going to be used as a criteria in determining reasonableness of quoted prices which would be determined by the buyer based on its own assessment of reasonableness and based on competitive prices received in Bid / RA process.

High Mast Lighting Tower For Large Area With LED Flood Lighting System (6 pieces)

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम कैटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	Height of High Mast Tower (in Meters)	16
	Installation and commissioning (Installation and commissioning work at multiple locations shall follow as per the guidelines of State/Central Govt rules and regulations as applicable)	Yes. Excluding Civil work
	Onsite warranty (in Years)	2, 3, 5
High mast System	No of sections	2
	Effective length of each section (in m)	10, 10.5, 8.5, 5
	Material construction: The mast shall be manufactured using special steel plates, conforming to	355 grade as per BSEN10 025
	Bottom diameter (in mm) - Minimum	610, 540, 570
	Plate thickness for Middle (in mm) - Minimum	4
	Plate thickness for Bottom (in mm) - Minimum	5, 6
	No of longitudinal welds / section (in Nos)	1, 2
	Diameter of base plate (in mm) - Minimum	840, 740, 770
	Thickness of base plate (in mm) - Minimum	25
Wind Load	Maximum Wind load	47 m/sec
Door Opening	Size of opening and closing door at base compartment of high mast (in mm) - Minimum	1200 x 250, 1200 x 300

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
Junction Box	Ingress protection for Junction Box i.e. IP Class (as per IS/IEC:60529:2001 latest) Test Report from Central Government lab/NABL/ILAC accredited lab and report shall furnish to buyer on demand	IP 55, IP 65
	No of core	3, 4, 5
	Cable category	FR
	Size of cable (in Sq mm)	1.5, 2.5, 4
	Conductor material shall be	Copper
Winch	The winch shall have provision for manual operation in case of failure of the motor	Yes
Stainless Steel Wire Rope	The breaking load of each rope shall be at full load as per the relevant standard	>/=2400 Kg
Electrical System, Cable and Cable Connections	No. of cores	1, 2, 3, 4, 5
	Cable shall be	Armoured, Unarmoured
	Conductor material shall be	Copper, Aluminium
	Cable Category	1, C1, C2
	Incoming power cable from feeder panel to base compartment of mast and cable shall conforming to	IS:7098 (Part 1):1988 latest
Feeder pillar Panel	Feeder pillar panel for each mast	Yes
	Feeder panel shall be suitable for	230 V, 1 phase, AC 50 Hz
	The control panels shall be	Stand mounted, No without feeder pillar panel
	Ingress protection for feeder pillar panel i.e IP Class (as per IS/IEC:60529:2001 latest).Test Report shall furnish from Central Government lab/NABL/ILAC accredited lab to buyer on demand	IP 55, IP 65, No without feeder pillar panel
	It shall be fabricated out of	14 SWG CRCA sheet steel, No without feeder pillar panel
	Thickness of sheet (in mm)	2

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
	The panels shall be given pre-treatment and powder coated and color shall be	Grey, No without feeder pillar panel
	The stand shall be painted in	Black color, No without feeder pillar panel
	Cable entry shall be at the	Bottom, No without feeder pillar panel
	The panels shall have	knock outs of the required cable, No without feeder pillar panel
	Laminated circuit diagram shall be pasted	inside of the door, No without feeder pillar panel
	Feeder pillar shall have pad locking arrangement	Yes
	Earth terminal	12 mm dia. Bolts
	Panel shall have a sloping cover to avoid accumulation of dust	Yes, No without feeder pillar panel
	Panel shall be provided with incoming & outgoing MCCB / MCB of appropriate rating and in desired quantity depending on total no of circuits in use	yes
	Timer for automatic ON & OFF of lights with pilot lamps shall be provided	Yes
	Bus bars material	Yes. Copper
	No of Cores	1, 2, 3, 4, 5, No without feeder pillar panel
	Size of cable (in Sq.mm)	1.5, 2.5, 4, 6, 10, 16, No without feeder pillar panel
	Cable Shall be	Armoured, Unarmoured, No without feeder pillar panel
	The conductor material shall be	Copper, Aluminium, No without feeder pillar panel
LED FLOOD LIGHT LUMINAIRE	cable category	1, C1, C2, No without feeder pillar panel
	No. of Luminaires for each high mast lighting tower (in Nos)	4, 6, 8, 10, 12, 16, 18
	LED Rating/System Wattage/Rated Power for each luminaire	100W, 110W, 120W, 125W, 130W, 140W, 150W, 180W, 200W, 250W, 300W, 350W, 400W, 500W, 1000W
	Luminaire System Efficacy (Lumen/watt)	>= 100 Lm/Watt
	Ingress Protection (IP Rating) as per IS:10322 (Part 1):1982 latest	IP65

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
	Mounting brackets (included)	Adjustable
	Input operating Voltage range and frequency	90 to 300 Volts AC at 50Hz+/-2Hz, 140 to 270 Volts AC at 50 Hz+/-2 Hz with auto cutt off at below 120V
	Rated voltage	230 V AC 50 Hz
	Colour temperature	6000K (+/- 500K), 5000K (+/- 500K), 4000K (+/- 500K), 3000K (+/- 500K)
	Optic lense material (UV stabilised) (Write NA for without optic lense supply)	Poly carbonate lense
	Operating temperature range	-20 deg C to +50 deg C, -10 deg C to +50 deg C, -10 deg C to +55 deg C
	The luminaire shall be protected against surges and transients(Internal)	>/=5KV, >/=4KV
	The luminaire shall be protected against surges and transients of >/=10KV (External)	Yes
	Extruded silicon loop gasket shall be provided in the lantern body to ensure a weather proof seal between the UV Glass cover and the metal housing to exclude the entry of the dust,water,insects etc	Yes
	Number of electronic control gear per luminaire (power supplies)	1 No., 2 Nos., 3 Nos., 4 Nos.
	Length of ISI marked three core wire (shall be provided along with supply of material)	50 cm, 100 cm

Additional Specification Parameters - High Mast Lighting Tower For Large Area With LED Flood Lighting System (6 pieces)

Specification Parameter Name	Bid Requirement (Allowed Values)
Wind load factor of safety	1.25
Galvanization thickness of high mast	Minimum 85 microns (as per IS: 2629)
Foundation design and soil bearing capacity:	As per IS:456 with design safety factor of 2.

Specification Parameter Name	Bid Requirement (Allowed Values)
Lightning Protection Finial	Hot dip galvanized with minimum length of 1.2m.
Aviation Obstruction Light	: 2 nos. medium Intensity Type-B, with cover of IP 65 protection.

* Bidders offering must also comply with the additional specification parameters mentioned above.

उपरोक्त मद के लिए इंस्टॉलेशन कमीशनिंग एंड टेस्टिंग (आईसीटी) का विवरण / **Installation Commissioning and Testing (ICT) details for the above item:**

% of Product Cost Payable on Product Delivery	90%
Min Cost Allocation for ICT as a % of product cost	21.61%
Number of days allowed for ICT after site readiness communication to seller	14 Days

परिषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परिषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	SOUMEN HAZRA	391320,P.O Jawaharnagar 391320	6	56

LED Luminaire For Road And Street Lights (V2) Conforming To IS 10322 (Part 5 / Section 3) (36 pieces)

Bis Required	Yes
--------------	-----

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
LED RATING	LED Rating (in Watts)/ System Wattage/ Rated Power	18, 24, 30, 36, 40, 45, 48, 60, 70, 72, 90, 100, 110, 120, 140, 150, 180, 200
	LED luminaire luminous Efficacy (Lumen/watt) (Hint: Total Lumen Calculation: Example: 18 W LED Rating x 100 Lumen/Watt = 1800 Lumens, 18 W LED Rating x 120 Lumen / Watt = 2160 Lumens, 18 W LED Rating x 140 Lumen/Watt = 2520 Lumens)	100, 120, 140 Or higher
ELECTRICAL CHARACTERISTIC	Input operating voltage range and frequency	140 to 270 Volts AC at 50 Hz +/-2

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
CONTROL GEAR	Number of electronic control gear in the luminaire (power supplies)	1, 2 Or higher
LUMINAIRE	Provision of luminaire connecting wire along with the supply of material	40 cm (ISI marked to IS 9968), 50 cm (ISI marked to IS 9968), 100 cm (ISI marked to IS 9968)
REPORTS AND CERTIFICATIONS	Warranty for free replacement (in years)	2, 3, 4, 5 Or higher

Additional Specification Parameters - LED Luminaire For Road And Street Lights (V2) Conforming To IS 10322 (Part 5 / Section 3) (36 pieces)

Specification Parameter Name	Bid Requirement (Allowed Values)
Colour temperature	In the range of 5665K±355K
Colour rendering index	CRI> 70
Minimum Efficiency for driver power	>= 87%
Power factor of complete fitting	Greater than 0.90
Housing Protection	IP65 or better

* Bidders offering must also comply with the additional specification parameters mentioned above.

उपरोक्त मद के लिए इंस्टॉलेशन कमीशनिंग एंड टेस्टिंग (आईसीटी) का विवरण / Installation Commissioning and Testing (ICT) details for the above item:

% of Product Cost Payable on Product Delivery	90%
Min Cost Allocation for ICT as a % of product cost	21.61%
Number of days allowed for ICT after site readiness communication to seller	14 Days

प्रेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	प्रेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	SOUMEN HAZRA	391320,P.O Jawaharnagar 391320	36	56

क्रेता द्वारा जोड़ी गई बिड की विशेष शर्तें/**Buyer Added Bid Specific Terms and Conditions**

1. **Generic**

OPTION CLAUSE: The Purchaser reserves the right to increase or decrease the quantity to be ordered up to 25 percent of bid quantity at the time of placement of contract. The purchaser also reserves the right to increase the ordered quantity up to 25% of the contracted quantity during the currency of the contract at the contracted rates. The delivery period of quantity shall commence from the last date of original delivery order and in cases where option clause is exercised during the extended delivery period the additional time shall commence from the last date of extended delivery period. The additional delivery time shall be $(\text{Increased quantity} \div \text{Original quantity}) \times \text{Original delivery period (in days)}$, subject to minimum of 30 days. If the original delivery period is less than 30 days, the additional time equals the original delivery period. The Purchaser may extend this calculated delivery duration up to the original delivery period while exercising the option clause. Bidders must comply with these terms.

2. **Buyer Added Bid Specific ATC**

Buyer uploaded ATC document [Click here to view the file.](#)

अस्वीकरण/**Disclaimer**

The additional terms and conditions have been incorporated by the Buyer after approval of the Competent Authority in Buyer Organization, whereby Buyer organization is solely responsible for the impact of these clauses on the bidding process, its outcome, and consequences thereof including any eccentricity / restriction arising in the bidding process due to these ATCs and due to modification of technical specifications and / or terms and conditions governing the bid. If any clause(s) is / are incorporated by the Buyer regarding following, the bid and resultant contracts shall be treated as null and void and such bids may be cancelled by GeM at any stage of bidding process without any notice:-

1. Definition of Class I and Class II suppliers in the bid not in line with the extant Order / Office Memorandum issued by DPIIT in this regard.
2. Seeking EMD submission from bidder(s), including via Additional Terms & Conditions, in contravention to exemption provided to such sellers under GeM GTC.
3. Publishing Custom / BOQ bids for items for which regular GeM categories are available without any Category item bunched with it.
4. Creating BoQ bid for single item.
5. Mentioning specific Brand or Make or Model or Manufacturer or Dealer name.
6. Mandating submission of documents in physical form as a pre-requisite to qualify bidders.
7. Floating / creation of work contracts as Custom Bids in Services.
8. Seeking sample with bid or approval of samples during bid evaluation process. (However, in bids for [attached categories](#), trials are allowed as per approved procurement policy of the buyer nodal Ministries)
9. Mandating foreign / international certifications even in case of existence of Indian Standards without specifying equivalent Indian Certification / standards.
10. Seeking experience from specific organization / department / institute only or from foreign / export experience.
11. Creating bid for items from irrelevant categories.
12. Incorporating any clause against the MSME policy and Preference to Make in India Policy.
13. Reference of conditions published on any external site or reference to external documents/clauses.
14. Asking for any Tender fee / Bid Participation fee / Auction fee in case of Bids / Forward Auction, as the case may be.
15. Buyer added ATC Clauses which are in contravention of clauses defined by buyer in system generated bid template as indicated above in the Bid Details section, EMD Detail, ePBG Detail and MII and MSE Purchase Preference sections of the bid, unless otherwise allowed by GeM GTC.
16. In a category based bid, adding additional items, through buyer added additional scope of work/ additional terms and conditions/or any other document. If buyer needs more items along with the main item, the same must be added through bunching category based items or by bunching custom catalogs or

bunching a BoQ with the main category based item, the same must not be done through ATC or Scope of Work.

Further, if any seller has any objection/grievance against these additional clauses or otherwise on any aspect of this bid, they can raise their representation against the same by using the Representation window provided in the bid details field in Seller dashboard after logging in as a seller within 4 days of bid publication on GeM. Buyer is duty bound to reply to all such representations and would not be allowed to open bids if he fails to reply to such representations.

All GeM Sellers / Service Providers are mandated to ensure compliance with all the applicable laws / acts / rules including but not limited to all Labour Laws such as The Minimum Wages Act, 1948, The Payment of Wages Act, 1936, The Payment of Bonus Act, 1965, The Equal Remuneration Act, 1976, The Payment of Gratuity Act, 1972 etc. Any non-compliance will be treated as breach of contract and Buyer may take suitable actions as per GeM Contract.

[यह बिड सामान्य शर्तों के अंतर्गत भी शासित है /This Bid is also governed by the General Terms and Conditions](#)

जेम की सामान्य शर्तों के खंड 26 के संदर्भ में भारत के साथ भूमि सीमा साझा करने वाले देश के बिडर से खरीद पर प्रतिबंध के संबंध में भारत के साथ भूमि सीमा साझा करने वाले देश का कोई भी बिडर इस निविदा में बिड देने के लिए तभी पात्र होगा जब वह बिड देने वाला सक्षम प्राधिकारी के पास पंजीकृत हो। बिड में भाग लेते समय बिडर को इसका अनुपालन करना होगा और कोई भी गलत घोषणा किए जाने व इसका अनुपालन न करने पर अनुबंध को तत्काल समाप्त करने और कानून के अनुसार आगे की कानूनी कार्यवाई का आधार होगा।/In terms of GeM GTC clause 26 regarding Restrictions on procurement from a bidder of a country which shares a land border with India, any bidder from a country which shares a land border with India will be eligible to bid in this tender only if the bidder is registered with the Competent Authority. While participating in bid, Bidder has to undertake compliance of this and any false declaration and non-compliance of this would be a ground for immediate termination of the contract and further legal action in accordance with the laws.

---धन्यवाद/Thank You---