

**बिड दस्तावेज़ / Bid Document**

| बिड विवरण / Bid Details   |  |
|---|--|
| बिड बंद होने की तारीख/समय / Bid End Date/Time   | 14-11-2025 16:00:00  |
| बिड खुलने की तारीख/समय / Bid Opening Date/Time  | 14-11-2025 16:30:00  |
| बिड पेशकश वैधता (बंद होने की तारीख से) / Bid Offer Validity (From End Date)   | 90 (Days)  |
| मंत्रालय/राज्य का नाम / Ministry/State Name   | Ministry Of Petroleum And Natural Gas  |
| विभाग का नाम / Department Name  | Balmer Lawrie And Company Limited  |
| संगठन का नाम / Organisation Name  | Balmer Lawrie And Company Limited  |
| कार्यालय का नाम / Office Name   | East   |
| कुल मात्रा / Total Quantity   | 100  |
| वस्तु श्रेणी / Item Category  | Portable Fire Extinguishers (V2) ISI Marked to IS 15683 (Q2) , Wall Mounted Automatic Fire Extinguisher (Q2)   |
| एमएसएमई के लिए अनुभव के वर्षों और टर्नओवर से छूट प्रदान की गई है / MSE Exemption for Years of Experience and Turnover   | No   |
| स्टार्टअप के लिए अनुभव के वर्षों और टर्नओवर से छूट प्रदान की गई है / Startup Exemption for Years of Experience and Turnover   | No   |
| विक्रेता से मांगे गए दस्तावेज़ / Document required from seller  | Certificate (Requested in ATC), OEM Authorization Certificate, Compliance of BoQ specification and supporting document<br>*In case any bidder is seeking exemption from Experience / Turnover Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer |
| क्या आप निविदाकारों द्वारा अपलोड किए गए दस्तावेज़ों को निविदा में भाग लेने वाले सभी निविदाकारों को दिखाना चाहते हैं? संदर्भ मेनू है / Do you want to show documents uploaded by bidders to all bidders participated in bid? | Yes (Documents submitted as part of a clarification or representation during the tender/bid process will also be displayed to other participated bidders after log in)   |
| बिड लगाने की समय सीमा स्वतः नहीं बढ़ाने के लिए आवश्यक बिड की संख्या। / Minimum number of bids required to disable automatic bid extension   | 3  |

| बिड विवरण/Bid Details  |   |
|--|---|
| दिनों की संख्या, जिनके लिए बिड लगाने की समय-सीमा बढ़ाई जाएगी। / <b>Number of days for which Bid would be auto-extended</b>   | 7   |
| ऑटो एक्सटेंशन अधिकतम कितनी बार किया जाना है। / <b>Number of Auto Extension count</b>   | 2   |
| बिड से रिवर्स नीलामी सक्रिय किया/Bid to RA enabled   | No  |
| बिड का प्रकार/Type of Bid  | Single Packet Bid                                       |
| प्राथमिक उत्पाद श्रेणी/Primary product category  | Portable Fire Extinguishers (V2) ISI Marked to IS 15683 |
| तकनीकी मूल्यांकन के दौरान तकनीकी स्पष्टीकरण हेतु अनुमत समय /Time allowed for Technical Clarifications during technical evaluation  | 2 Days  |
| निरीक्षण आवश्यक (सूचीबद्ध निरीक्षण प्राधिकरण /जेम के साथ पूर्व पंजीकृत एजेंसियों द्वारा)/Inspection Required (By Empanelled Inspection Authority / Agencies pre-registered with GeM) | No  |
| मूल्यांकन पद्धति/Evaluation Method   | Total value wise evaluation                             |
| मध्यस्थता खंड/Arbitration Clause   | No  |
| सुलह खंड/Mediation Clause  | No  |

#### ईएमडी विवरण/EMD Detail

|                             |           |
|-----------------------------|-----------|
| एडवाइजरी बैंक/Advisory Bank | HDFC Bank |
| ईएमडी राशि/EMD Amount       | 6000      |

#### ईपीबीजी विवरण /ePBG Detail

|   |           |
|---|-----------|
| एडवाइजरी बैंक/Advisory Bank                                       | HDFC Bank |
| ईपीबीजी प्रतिशत (%) /ePBG Percentage(%)                           | 5.00      |
| ईपीबीजी की आवश्यक अवधि (माह) /Duration of ePBG required (Months). | 62        |

(a). जेम की शर्तों के अनुसार ईएमडी छूट के इच्छुक बिडर को संबंधित कैटेगरी के लिए बिड के साथ वैध समर्थित दस्तावेज प्रस्तुत करने हैं। एमएसई कैटेगरी के अंतर्गत केवल वस्तुओं के लिए विनिर्माता तथा सेवाओं के लिए सेवा प्रदाता ईएमडी से छूट के पात्र हैं। व्यापारियों को इस नीति के दायरे से बाहर रखा गया है।/EMD EXEMPTION: The bidder seeking EMD exemption, must submit the valid supporting document for the relevant category as per GeM GTC with the bid. Under MSE category, only manufacturers for goods and Service Providers for Services are eligible for exemption from EMD. Traders are excluded from the purview of this Policy.

(b). ईएमडी और संपादन जमानत राशि, जहां यह लागू होती है, लाभार्थी के पक्ष में होनी चाहिए। / EMD & Performance security should be in favour of Beneficiary, wherever it is applicable.

**लभार्थी /Beneficiary :**

DEPUTY MANAGER (SCM)  
P-43, HIDE ROAD EXTENSION, KOLKATA - 700 088  
(Balmer Lawrie And Co. Ltd.)

**UIN Number NCTGC2415P**

बोली विभाजन लागू नहीं किया गया/ Bid splitting not applied.

**एमआईआई खरीद वरीयता/MII Purchase Preference**

|  |    |
|--|----|
| एमआईआई खरीद वरीयता/MII Purchase Preference | No |
|--|----|

**एमआईआई के लिए सक्षम प्राधिकारी का विवरण:/Details of the Competent Authority for MII**

|   |  |
|---|--|
| सक्षम प्राधिकारी का नाम/Name of Competent Authority   | RAJEEV KUMAR SINGH   |
| सक्षम प्राधिकारी का पदनाम/Designation of Competent Authority  | HEAD (SALES & MARKETING)   |
| सक्षम प्राधिकारी का कार्यालय/विभाग/प्रभाग/Office / Department / Division of Competent Authority                                   | SBU - G&L  |
| सीए अनुमोदन संख्या/CA Approval Number   | 03112025   |
| सक्षम प्राधिकारी अनुमोदन तिथि/Competent Authority Approval Date   | 03-11-2025   |
| सक्षम प्राधिकारी द्वारा प्रदान की गई स्वीकृति का संक्षिप्त विवरण/Brief Description of the Approval Granted by Competent Authority | As per MoPNG Circular dated 26.04.2022, w.r.t. Public Procurement (Preference to Make in India) (PPP-MII) Order, 2017, the limit for exemption of this Order, as applicable to small purchases, would be upto Rs.1.00 cr.*, in terms of Order Value. |

Competent Authority Approval for not opting Make In India Preference : [View Document](#)

**एमएसई खरीद वरीयता/MSE Purchase Preference**

|  |     |
|--|-----|
| एमएसई खरीद वरीयता/MSE Purchase Preference  | Yes |
| सूक्ष्म और लघु उद्यम मूल उपकरण निर्माताओं को खरीद में प्राथमिकता, यदि उनका मूल्य $L1+X\%$ तक की सीमा में हो / Purchase Preference to MSE OEMs available upto price within $L1+X\%$ | 15  |
| सूक्ष्म और लघु उद्यम को खरीद में प्राथमिकता के लिए बिड की मात्रा का अधिकतम प्रतिशत / Maximum Percentage of Bid quantity for MSE purchase preference                                | 25  |

1. Purchase preference will be given to MSEs having valid Udyam Registration and whose credentials are validated online through Udyam Registration portal as defined in Public Procurement Policy for Micro and Small Enterprises (MSEs) Order, 2012 dated 23.03.2012 issued by Ministry of Micro, Small and Medium Enterprises and its subsequent Orders/Notifications issued by concerned Ministry. If the bidder wants to avail themselves of the Purchase preference, the bidder must be the manufacturer / OEM of the offered product on GeM. Traders are excluded from the purview of Public Procurement Policy for Micro and Small Enterprises and hence resellers

offering products manufactured by some other OEM are not eligible for any purchase preference. In respect of bid for Services, the bidder must be the Service provider of the offered Service. Relevant documentary evidence in this regard shall be uploaded along with the bid in respect of the offered product or service and Buyer will decide eligibility for purchase preference based on documentary evidence submitted, while evaluating the bid. If L-1 is not an MSE and MSE Seller (s) has / have quoted price within L-1+ 15% (Selected by Buyer) of margin of purchase preference /price band defined in relevant policy, such MSE Seller shall be given opportunity to match L-1 price and contract will be awarded for 25% (selected by Buyer) percentage of total quantity. The buyers are advised to refer the OM No. F.1/4/2021-PPD dated 18.05.2023 [OM No.1 4 2021 PPD dated 18.05.2023](#) for compliance of Concurrent application of Public Procurement Policy for Micro and Small Enterprises Order, 2012 and Public Procurement (Preference to Make in India) Order, 2017. Benefits of MSE will be allowed only if seller is validated on-line in GeM profile as well as validated and approved by Buyer after evaluation of documents submitted.

### Portable Fire Extinguishers (V2) ISI Marked To IS 15683 ( 30 pieces )

|              |     |
|--------------|-----|
| Bis Required | Yes |
|--------------|-----|

#### तकनीकी विशिष्टियाँ /Technical Specifications

\* जेम कैटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

| विवरण/Specification     | विशिष्टि का नाम /Specification Name   | बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)     |
|-------------------------|---|---|
| Generic                 | Type  | Stored Pressure   |
|                         | Extinguishing Media   | Foam Based (as per IS 4989)   |
|                         | Expellant Medium  | N2 Based (Stored Pressure)  |
| Constructional Material | Type of Extinguisher  | Low Pressure Extinguisher (Service Pressure ?19 bar)                |
|                         | Material Specification for the body of High Pressure Extinguisher             | NA  |
|                         | Material Specification for the body of Low Pressure Extinguisher              | Welded low carbon steel cylinders (as per Clause 9.2.5 of IS 15683) |
| Construction            | Foam Based Extinguishing Media  | Aqueous Film Forming Foam (AFFF)                                    |
|                         | Powder Based Extinguishing Media  | NA  |
|                         | Type of Clean Agent for Clean Agent Based Fire Extinguisher (as per CL 5-1-3) | NA  |
|                         | Foam Based Fire Extinguisher Capacity in Liters                               | 9   |
|                         | Powder Based Fire Extinguisher Capacity in Kg                                 | NA  |
|                         | Carbon Dioxide Based Fire Extinguisher Capacity in Kg                         | NA  |
|                         | Water Based Fire Extinguisher Capacity in Liters                              | NA  |

| विवरण/Specification | विशिष्टि का नाम /Specification Name                    | बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)  |
|---------------------|--|--|
|                     | Clean Agents Fire Extinguisher Capacity in Kg          | NA   |
|                     | Water Mist Fire Extinguisher Capacity in Liters        | NA   |
|                     | Features of Fire Extinguisher                          | Carrying Handle (Mandatory If Extinguisher having mass ?1.5Kg or Cylinder diameter, Rechargeable, Hose Assemblies (Mandatory If mass or volume of Extinguishing medium > 3 Kg or Litres) |
|                     | Class of fire for which Fire Extinguisher is suitable  | Class -A   |
| Performance         | Operating Temperature (°C)                             | +5°C to +60°C  |
|                     | Minimum Effective discharge time for Fire Extinguisher | 36.0 (second)  |
|                     | Fire Rating of different class of fires                | 233B   |

**परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity**

| क्र.सं./S.No. | परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer | पता/Address   | मात्रा /Quantity | डिलीवरी के दिन/Delivery Days |
|---------------|---|---|------------------|------------------------------|
| 1             | Amit Panda  | 700088,P 43, Extension, Hide Road, Kolkata, West Bengal | 30               | 30                           |

**Portable Fire Extinguishers (V2) ISI Marked To IS 15683 ( 30 pieces )**

|              |     |
|--------------|-----|
| Bis Required | Yes |
|--------------|-----|

**तकनीकी विशिष्टियाँ /Technical Specifications**

\* जेम कैटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

| विवरण/Specification     | विशिष्टि का नाम /Specification Name | बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values) |
|-------------------------|-------------------------------------|---|
| Generic                 | Type                                | Stored Pressure   |
|                         | Extinguishing Media                 | Carbon Dioxide Based (as per IS 15222)                          |
|                         | Expellant Medium                    | CO2 Extinguishing Medium  |
| Constructional Material | Type of Extinguisher                | High Pressure Extinguisher (Service Pressure >19 bar)           |

| विवरण/Specification | विशिष्टि का नाम /Specification Name  | बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)   |
|---------------------|--|---|
|                     | <b>Material Specification for the body of High Pressure Extinguisher</b>             | Steel body (as per latest IS 7285)  |
|                     | <b>Material Specification for the body of Low Pressure Extinguisher</b>              | NA  |
| Construction        | <b>Foam Based Extinguishing Media</b>  | NA  |
|                     | <b>Powder Based Extinguishing Media</b>  | NA  |
|                     | <b>Type of Clean Agent for Clean Agent Based Fire Extinguisher (as per CL 5-1-3)</b> | NA  |
|                     | <b>Foam Based Fire Extinguisher Capacity in Liters</b>                               | NA  |
|                     | <b>Powder Based Fire Extinguisher Capacity in Kg</b>                                 | NA  |
|                     | <b>Carbon Dioxide Based Fire Extinguisher Capacity in Kg</b>                         | 4.5   |
|                     | <b>Water Based Fire Extinguisher Capacity in Liters</b>                              | NA  |
|                     | <b>Clean Agents Fire Extinguisher Capacity in Kg</b>                                 | NA  |
|                     | <b>Water Mist Fire Extinguisher Capacity in Liters</b>                               | NA  |
|                     | <b>Features of Fire Extinguisher</b>   | Carrying Handle (Mandatory If Extinguisher having mass >1.5Kg or Cylinder diameter, Safety Devices (Mandatory for High Pressure Extinguisher), Rechargeable, Hose Assemblies (Mandatory If mass or volume of Extinguishing medium > 3 Kg or Litres) |
|                     | <b>Class of fire for which Fire Extinguisher is suitable</b>                         | Class -B  |
| Performance         | <b>Operating Temperature (°C)</b>  | -30°C to +60°C  |
|                     | <b>Minimum Effective discharge time for Fire Extinguisher</b>                        | 13.534 (second)   |
|                     | <b>Fire Rating of different class of fires</b>                                       | 55B   |

परिषदी/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

| क्र.सं./S.No. | परिषदी/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer | पता/Address   | मात्रा /Quantity | डिलीवरी के दिन/Delivery Days |
|---------------|--|---|------------------|------------------------------|
| 1             | Amit Panda   | 700088,P 43, Extension, Hide Road, Kolkata, West Bengal | 30               | 30                           |

**Wall Mounted Automatic Fire Extinguisher ( 10 pieces )**

तकनीकी विशिष्टियाँ /Technical Specifications

\* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

| विवरण/Specification     | विशिष्टि का नाम /Specification Name  | बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values) |
|-------------------------|--|---|
| Generic                 | Extinguishing Media  | Powder Based (as per IS 4308 )                                  |
|                         | Expellant Medium   | N2 Based  |
|                         | Extinguishing Agent of Powder Based Fire Extinguisher  | ABC MAP90   |
|                         | Discharge Mechanism  | Automatic   |
|                         | Additional Requirement (Hint: Select NA if not applicable)   | NA  |
| Constructional Material | Cylinder/Vessel Material   | Mild Steel  |
|                         | Valve Material   | Stainless Steel   |
|                         | Internal Coating   | Epoxy Powder Coating  |
|                         | External Coating   | Epoxy Polyester Powder  |
| Construction            | Powder Based Fire Extinguisher Capacity (in Kg) (Hint: Select NA if Extinguishing Media is not powder based)     | 6   |
|                         | Clean Agent Based Fire Extinguisher Capacity (in Kg) (Hint: Select NA if Extinguishing Media is not clean agent) | NA  |
|                         | Fitted with heat sensor Quartzoid Bulbs with Sprinkler heads   | 2   |
|                         | Class of fire for which Fire Extinguisher is suitable  | Class -A, Class -B, Class -C, Class -E                          |
|                         | Additional Features and Accessories  | Rechargeable  |

| विवरण/Specification | विशिष्टि का नाम /Specification Name   | बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values) |
|---------------------|---|---|
| Performance         | Quartzoid bulbs temperature rating  | 68.0 (degree Celsius)   |
|                     | Operating Temperature   | -20°C to +60°C  |
|                     | Fire Rating for Class -A Fire Extinguisher as per EN3 (Hint: Select NA if Not Applicable) | 21A   |
|                     | Fire Rating for Class -B Fire Extinguisher as per EN3 (Hint: Select NA if Not Applicable) | 113B  |
|                     | Fire Rating for Class -A Fire Extinguisher as per BIS (Hint: Select NA if Not Applicable) | 4A  |
|                     | Fire Rating for Class -B Fire Extinguisher as per BIS (Hint: Select NA if Not Applicable) | 113B  |

**परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity**

| क्र.सं./S.No. | परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer | पता/Address   | मात्रा /Quantity | डिलीवरी के दिन/Delivery Days |
|---------------|---|---|------------------|------------------------------|
| 1             | Amit Panda  | 700088,P 43, Extension, Hide Road, Kolkata, West Bengal | 10               | 30                           |

**Portable Fire Extinguishers (V2) ISI Marked To IS 15683 ( 30 pieces )**

|              |     |
|--------------|-----|
| Bis Required | Yes |
|--------------|-----|

**तकनीकी विशिष्टियाँ /Technical Specifications**

\* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

| विवरण/Specification | विशिष्टि का नाम /Specification Name | बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values) |
|---------------------|-------------------------------------|---|
| Generic             | Type                                | Stored Pressure   |
|                     | Extinguishing Media                 | Powder Based (as per IS 4308 )                                  |
|                     | Expellant Medium                    | N2 Based (Stored Pressure)                                      |



| विवरण/Specification     | विशिष्टि का नाम /Specification Name  | बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)   |
|-------------------------|--|---|
| Constructional Material | <b>Type of Extinguisher</b>  | Low Pressure Extinguisher (Service Pressure ?19 bar)  |
|                         | <b>Material Specification for the body of High Pressure Extinguisher</b>             | NA  |
|                         | <b>Material Specification for the body of Low Pressure Extinguisher</b>              | Welded low carbon steel cylinders (as per Clause 9.2.5 of IS 15683)   |
| Construction            | <b>Foam Based Extinguishing Media</b>  | NA  |
|                         | <b>Powder Based Extinguishing Media</b>  | ABC   |
|                         | <b>Type of Clean Agent for Clean Agent Based Fire Extinguisher (as per CL 5-1-3)</b> | NA  |
|                         | <b>Foam Based Fire Extinguisher Capacity in Liters</b>                               | NA  |
|                         | <b>Powder Based Fire Extinguisher Capacity in Kg</b>                                 | 6   |
|                         | <b>Carbon Dioxide Based Fire Extinguisher Capacity in Kg</b>                         | NA  |
|                         | <b>Water Based Fire Extinguisher Capacity in Liters</b>                              | NA  |
|                         | <b>Clean Agents Fire Extinguisher Capacity in Kg</b>                                 | NA  |
|                         | <b>Water Mist Fire Extinguisher Capacity in Liters</b>                               | NA  |
|                         | <b>Features of Fire Extinguisher</b>   | Carrying Handle (Mandatory If Extinguisher having mass ?1.5Kg or Cylinder diameter, Safety Devices (Mandatory for High Pressure Extinguisher), Rechargeable, Hose Assemblies (Mandatory If mass or volume of Extinguishing medium > 3 Kg or Litres) |
|                         | <b>Class of fire for which Fire Extinguisher is suitable</b>                         | Class -A  |
| Performance             | <b>Operating Temperature (°C)</b>  | +0°C to +60°C   |
|                         | <b>Minimum Effective discharge time for Fire Extinguisher</b>                        | 13.0 (second)   |
|                         | <b>Fire Rating of different class of fires</b>                                       | 3A  |

**परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity**

| क्र.सं./S.No. | परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer | पता/Address   | मात्रा /Quantity | डिलीवरी के दिन/Delivery Days |
|---------------|---|---|------------------|------------------------------|
| 1             | Amit Panda  | 700088,P 43, Extension, Hide Road, Kolkata, West Bengal | 30               | 30                           |

**Special terms and conditions-Version:3 effective from 28-04-2025 for category Portable Fire Extinguishers (V2) ISI Marked to IS 15683**

1. This is "buy-back" enabled category.

**Note to Buyers:**

- The Central Ministries/ Departments and other government buyers as applicable shall note that this category is covered under Scheme - I (ISI Mark Scheme) of BIS (Bureau of Indian Standards).
- Compulsory use of Standard Mark - Goods or articles shall conform to the corresponding Indian Standard and shall bear the Standard Mark under a license from the Bureau as per Scheme-1 of Schedule-II of the Bureau of Indian Standards (Conformity Assessment) Regulations, 2018:
- Buyer shall verify and confirm compliance with the applicable BIS order during the procurement and fulfillment process.

**Note to Sellers:**

- Sellers shall offer and supply products conforming to the corresponding Indian Standard and bear the Standard Mark under a license from the Bureau as per Scheme-1.
- Non-compliance shall result in action as per GeM IM policy.
- Buyers and sellers may refer to the relevant S.O at <https://www.bis.gov.in/product-certification/products-under-compulsory-certification/scheme-i-mark-scheme/>

**Applicable PESO Rules:**

Petroleum and Explosives Safety Organisation is a nodal agency for regulating safety of hazardous substances such as explosives, compressed gases and petroleum. The relevant rules for delivery or dispatch of cylinders or possession of cylinders under Gas Cylinder Rules 2016 framed under Explosives Act, 1884 administered by this Organization, are given below.:

Rule 10 : Restriction on delivery or dispatch of cylinder:- (1) No person shall deliver or dispatch any cylinder filled with any compressed gas to any other person in India who is not the holder of a licence to possess such gas cylinder or to his authorised agent unless he is exempted under these rules to possess compressed gas cylinder without a licence.

(2) The gas cylinder delivered or dispatched by a person under sub-rule (1) shall be of the type for which he is licensed and shall not exceed the quantity which the person to whom it is delivered or dispatched is authorised to possess under these rules.

(3) Nothing in sub-rules(1) and (2) shall apply to the delivery or dispatch of gas cylinder to the defence forces of the Union, port authorities or railway administration and other paramilitary forces:

Provided that this sub-rule shall not be applicable for co-operative societies run by the welfare associations of these organisations.

Rule 43: Licence for filling and possession (1) No person shall fill any cylinder with compressed gas and no cylinder filled with compressed gas shall be possessed by anyone except under and in accordance with the conditions of a licence granted under these rules.

(2) The licensee shall be responsible, for all operations connected with the filling and possession of

cylinders in the licensed premises.

Rule 44: No licence needed for possession in certain cases.- Notwithstanding anything contained in rule 43, licence shall not be necessary for-

(a) possession of any cylinder filled with a compressed gas by a carrier or other person for the purpose of transport in accordance with the provisions of these rules;

(b) possession of cylinders for own use and not meant for sale or trading filled with,-

(i) any flammable and non-toxic gas when the total number of cylinders containing such gas does not exceed twenty five or the total weight of gas does not exceed 200 kg., whichever is less, at a time;

(ii) any non-flammable non-toxic gas when the total number of such cylinders does not exceed two hundred at a time;

(iii) any toxic gas when the total quantity of such cylinders does not exceed five at a time;

(iv) acetylene gas contained in cylinder in dissolved state when the total quantity of such cylinder does not exceed twenty five at a time.

(c) The provisions of sub-clause 44(b) shall not be applicable for liquefied petroleum gas when the total quantity of gas does not exceed 100 kg at a time for own use, distribution or sale from a sales room belonging to the dealer or distributor of respective oil marketing company.

Notwithstanding anything contained in rule 43, licence shall not be obligatory for working places where LPG cylinders are directly connected to the manifold, but the requirements of IS :6044 Part-1 shall be complied with ,such manifold installations and shall be constructed adapting the sound engineering practices and the quantity of the LPG at any point of the time shall not exceed the limits prescribed in IS-6044 Part-1.

## क्रेता द्वारा जोड़ी गई बिड की विशेष शर्तें/Buyer Added Bid Specific Terms and Conditions

### 1. Generic

Actual delivery (and Installation & Commissioning (if covered in scope of supply)) is to be done at following address

P 43  
HIDE ROAD EXTENSION  
KOLKATA  
KOLKATA - 700088  
WEST BENGAL  
.

### 2. Generic

Bidders are advised to check applicable GST on their own before quoting. Buyer will not take any responsibility in this regards. GST reimbursement will be as per actuals or as per applicable rates (whichever is lower), subject to the maximum of quoted GST %.

### 3. Generic

Bidder shall submit the following documents along with their bid for Vendor Code Creation:

- a. Copy of PAN Card.
- b. Copy of GSTIN.
- c. Copy of Cancelled Cheque.

d. Copy of EFT Mandate duly certified by Bank.

#### 4. **Generic**

**Manufacturer Authorization:**Wherever Authorised Distributors/service providers are submitting the bid, Authorisation Form /Certificate with OEM/Original Service Provider details such as name, designation, address, e-mail Id and Phone No. required to be furnished along with the bid

#### 5. **Generic**

While generating invoice in GeM portal, the seller must upload scanned copy of GST invoice and the screenshot of GST portal confirming payment of GST.

#### 6. **Forms of EMD and PBG**

Bidders can also submit the EMD with Payment online through RTGS / internet banking in Beneficiary name

Balmer Lawrie and Co. Ltd.

Account No.

00140310005630

IFSC Code

HDFC0000014

Bank Name

HDFC Bank

Branch address

2/6, Sarat Bose Road,Central Plaza,Kolkata-700020

. Bidder to indicate bid number and name of bidding entity in the transaction details field at the time of on-line transfer. Bidder has to upload scanned copy / proof of the Online Payment Transfer along with bid.

#### 7. **Forms of EMD and PBG**

Successful Bidder can submit the Performance Security in the form of Payment online through RTGS / internet banking also (besides PBG which is allowed as per GeM GTC). On-line payment shall be in Beneficiary name

Balmer Lawrie and Co. Ltd.

Account No.

00140310005630

IFSC Code

HDFC0000014

Bank Name

HDFC Bank

Branch address

2/6, Sarat Bose Road,Central Plaza,Kolkata-700020

. Successful Bidder to indicate Contract number and name of Seller entity in the transaction details field at the time of on-line transfer. Bidder has to upload scanned copy / proof of the Online Payment Transfer in place of PBG within 15 days of award of contract.

#### 8. **Scope of Supply**

Scope of supply (Bid price to include all cost components) : Only supply of Goods

#### 9. **Warranty**

Warranty period of the supplied products shall be 5 years from the date of final acceptance of goods or after completion of installation, commissioning & testing of goods (if included in the scope of supply), at consignee location. OEM Warranty certificates must be submitted by Successful Bidder at the time of delivery of Goods. The seller should guarantee the rectification of goods in case of any break down during the guarantee period. Seller should have well established Installation, Commissioning, Training, Troubleshooting and Maintenance Service group in INDIA for attending the after sales service. Details of Service Centres near consignee destinations are to be uploaded along with the bid.

## अस्वीकरण/Disclaimer

The additional terms and conditions have been incorporated by the Buyer after approval of the Competent Authority in Buyer Organization, whereby Buyer organization is solely responsible for the impact of these clauses on the bidding process, its outcome, and consequences thereof including any eccentricity / restriction arising in the bidding process due to these ATCs and due to modification of technical specifications and / or terms and conditions governing the bid. If any clause(s) is / are incorporated by the Buyer regarding following, the bid and resultant contracts shall be treated as null and void and such bids may be cancelled by GeM at any stage of bidding process without any notice:-

1. Definition of Class I and Class II suppliers in the bid not in line with the extant Order / Office Memorandum issued by DPIIT in this regard.
2. Seeking EMD submission from bidder(s), including via Additional Terms & Conditions, in contravention to exemption provided to such sellers under GeM GTC.
3. Publishing Custom / BOQ bids for items for which regular GeM categories are available without any Category item bunched with it.
4. Creating BoQ bid for single item.
5. Mentioning specific Brand or Make or Model or Manufacturer or Dealer name.
6. Mandating submission of documents in physical form as a pre-requisite to qualify bidders.
7. Floating / creation of work contracts as Custom Bids in Services.
8. Seeking sample with bid or approval of samples during bid evaluation process. (However, in bids for [attached categories](#), trials are allowed as per approved procurement policy of the buyer nodal Ministries)
9. Mandating foreign / international certifications even in case of existence of Indian Standards without specifying equivalent Indian Certification / standards.
10. Seeking experience from specific organization / department / institute only or from foreign / export experience.
11. Creating bid for items from irrelevant categories.
12. Incorporating any clause against the MSME policy and Preference to Make in India Policy.
13. Reference of conditions published on any external site or reference to external documents/clauses.
14. Asking for any Tender fee / Bid Participation fee / Auction fee in case of Bids / Forward Auction, as the case may be.
15. Buyer added ATC Clauses which are in contravention of clauses defined by buyer in system generated bid template as indicated above in the Bid Details section, EMD Detail, ePBG Detail and MII and MSE Purchase Preference sections of the bid, unless otherwise allowed by GeM GTC.
16. In a category based bid, adding additional items, through buyer added additional scope of work/ additional terms and conditions/or any other document. If buyer needs more items along with the main item, the same must be added through bunching category based items or by bunching custom catalogs or bunching a BoQ with the main category based item, the same must not be done through ATC or Scope of Work.

Further, if any seller has any objection/grievance against these additional clauses or otherwise on any aspect of this bid, they can raise their representation against the same by using the Representation window provided in the bid details field in Seller dashboard after logging in as a seller within 4 days of bid publication on GeM. Buyer is duty bound to reply to all such representations and would not be allowed to open bids if he fails to reply to such representations.

**All GeM Sellers / Service Providers are mandated to ensure compliance with all the applicable laws / acts / rules including but not limited to all Labour Laws such as The Minimum Wages Act, 1948, The Payment of Wages Act, 1936, The Payment of Bonus Act, 1965, The Equal Remuneration Act, 1976, The Payment of Gratuity Act, 1972 etc. Any non-compliance will be treated as breach of contract and Buyer may take suitable actions as per GeM Contract.**

[यह बिड सामान्य शर्तों के अंतर्गत भी शासित है /This Bid is also governed by the General Terms and Conditions](#)

जेम की सामान्य शर्तों के खंड 26 के संदर्भ में भारत के साथ भूमि सीमा साझा करने वाले देश के बिडर से खरीद पर प्रतिबंध के संबंध में

भारत के साथ भूमि सीमा साझा करने वाले देश का कोई भी बिडर इस निविदा में बिड देने के लिए तभी पात्र होगा जब वह बिड देने वाला सक्षम प्राधिकारी के पास पंजीकृत हो। बिड में भाग लेते समय बिडर को इसका अनुपालन करना होगा और कोई भी गलत घोषणा किए जाने व इसका अनुपालन न करने पर अनुबंध को तत्काल समाप्त करने और कानून के अनुसार आगे की कानूनी कार्रवाई का आधार होगा।/In terms of GeM GTC clause 26 regarding Restrictions on procurement from a bidder of a country which shares a land border with India, any bidder from a country which shares a land border with India will be eligible to bid in this tender only if the bidder is registered with the Competent Authority. While participating in bid, Bidder has to undertake compliance of this and any false declaration and non-compliance of this would be a ground for immediate termination of the contract and further legal action in accordance with the laws.

**---धन्यवाद/Thank You---**