

बिड दस्तावेज़ / Bid Document

| बिड विवरण/Bid Details | |
|---|--|
| बिड बंद होने की तारीख/समय /Bid End Date/Time | 13-11-2025 18:00:00 |
| बिड खुलने की तारीख/समय /Bid Opening Date/Time | 13-11-2025 18:30:00 |
| बिड पेशकश वैधता (बंद होने की तारीख से)/Bid Offer Validity (From End Date) | 30 (Days) |
| मंत्रालय/राज्य का नाम/Ministry/State Name | Maharashtra |
| विभाग का नाम/Department Name | Medical Education And Drugs Department Maharashtra |
| संगठन का नाम/Organisation Name | Directorate Of Medical Education And Research |
| कार्यालय का नाम/Office Name | Shri Vasantao Naik Govt Medical College Yavatmal |
| कुल मात्रा/Total Quantity | 26 |
| वस्तु श्रेणी /Item Category | Reverse Osmosis based Water Treatment System above 50 LPH Capacity (V2) (Q2) , Water Purification System with UV (Ultra-Violet Process) or UV (Ultra-Violet Process)+UF (Ultra-Filtration Process) (V2) (Q2) |
| एमएसएमई के लिए अनुभव के वर्षों और टर्नओवर से छूट प्रदान की गई है/MSE Exemption for Years of Experience and Turnover | No |
| स्टार्टअप के लिए अनुभव के वर्षों और टर्नओवर से छूट प्रदान की गई है /Startup Exemption for Years of Experience and Turnover | No |
| विक्रेता से मांगे गए दस्तावेज़/Document required from seller | Bidder Turnover,Certificate (Requested in ATC),Additional Doc 1 (Requested in ATC),Additional Doc 2 (Requested in ATC),Additional Doc 3 (Requested in ATC),Additional Doc 4 (Requested in ATC),Compliance of BoQ specification and supporting document *In case any bidder is seeking exemption from Experience / Turnover Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer |
| क्या आप निविदाकारों द्वारा अपलोड किए गए दस्तावेज़ों को निविदा में भाग लेने वाले सभी निविदाकारों को दिखाना चाहते हैं? संदर्भ मेन् है/Do you want to show documents uploaded by bidders to all bidders participated in bid? | No |
| बिड लगाने की समय सीमा स्वतः नहीं बढ़ाने के लिए आवश्यक बिड की संख्या / Minimum number of bids required to disable automatic bid extension | 1 |

| बिड विवरण/Bid Details | |
|--|---|
| दिनों की संख्या, जिनके लिए बिड लगाने की समय-सीमा बढ़ाई जाएगी। / Number of days for which Bid would be auto-extended | 3 |
| ऑटो एक्सटेंशन अधिकतम कितनी बार किया जाना है। / Number of Auto Extension count | 1 |
| बिड से रिवर्स नीलामी सक्रिय किया/Bid to RA enabled | No |
| बिड का प्रकार/Type of Bid | Two Packet Bid |
| प्राथमिक उत्पाद श्रेणी/Primary product category | Reverse Osmosis based Water Treatment System above 50 LPH Capacity (V2) |
| तकनीकी मूल्यांकन के दौरान तकनीकी स्पष्टीकरण हेतु अनुमत समय /Time allowed for Technical Clarifications during technical evaluation | 2 Days |
| निरीक्षण आवश्यक (सूचीबद्ध निरीक्षण प्राधिकरण /जेम के साथ पूर्व पंजीकृत एजेंसियों द्वारा)/Inspection Required (By Empanelled Inspection Authority / Agencies pre-registered with GeM) | No |
| मूल्यांकन पद्धति/Evaluation Method | Total value wise evaluation |
| मध्यस्थता खंड/Arbitration Clause | No |
| सुलह खंड/Mediation Clause | No |

ईएमडी विवरण/EMD Detail

| | |
|-----------------------------|---------------------|
| एडवाइजरी बैंक/Advisory Bank | State Bank of India |
| ईएमडी राशि/EMD Amount | 350000 |

ईपीबीजी विवरण /ePBG Detail

| | |
|-------------------|----|
| आवश्यकता/Required | No |
|-------------------|----|

(a). जेम की शर्तों के अनुसार ईएमडी छूट के इच्छुक बिडर को संबंधित कैटेगरी के लिए बिड के साथ वैध समर्थित दस्तावेज़ प्रस्तुत करने है। एमएसई कैटेगरी के अंतर्गत केवल वस्तुओं के लिए विनिर्माता तथा सेवाओं के लिए सेवा प्रदाता ईएमडी से छूट के पात्र हैं। व्यापारियों को इस नीति के दायरे से बाहर रखा गया है।/EMD EXEMPTION: The bidder seeking EMD exemption, must submit the valid supporting document for the relevant category as per GeM GTC with the bid. Under MSE category, only manufacturers for goods and Service Providers for Services are eligible for exemption from EMD. Traders are excluded from the purview of this Policy.

(b). ईएमडी और संपादन जमानत राशि, जहां यह लागू होती है, लाभार्थी के पक्ष में होनी चाहिए। / EMD & Performance security should be in favour of Beneficiary, wherever it is applicable.

लाभार्थी /Beneficiary :

DEAN

Shri Vasantrao Naik Govt Medical College Yavatmal, Medical Education and Drugs Department Maharashtra, Directorate of Medical Education and Research,

(Dean Svngmc Yavatmal)

बोली विभाजन लागू नहीं किया गया/ Bid splitting not applied.

एमएसई खरीद वरीयता/MSE Purchase Preference

| | |
|---|----|
| एमएसई खरीद वरीयता/MSE Purchase Preference | No |
|---|----|

एमआईआई खरीद वरीयता/MII Purchase Preference

| | |
|--|----|
| एमआईआई खरीद वरीयता/MII Purchase Preference | No |
|--|----|

1. Estimated Bid Value indicated above is being declared solely for the purpose of guidance on EMD amount and for determining the Eligibility Criteria related to Turn Over, Past Performance and Project / Past Experience etc. This has no relevance or bearing on the price to be quoted by the bidders and is also not going to have any impact on bid participation. Also this is not going to be used as a criteria in determining reasonableness of quoted prices which would be determined by the buyer based on its own assessment of reasonableness and based on competitive prices received in Bid / RA process.

Reverse Osmosis Based Water Treatment System Above 50 LPH Capacity (V2) (1 pieces)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

| विवरण/Specification | विशिष्टि का नाम /Specification Name | बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values) |
|---|---|---|
| Generic | Construction RO Frame | SS202 or better, SS304 or better Or higher |
| | Construction of Body / Encloser | NA - Being without encloser, Food Grade Plastic or Better, SS202 or better, SS304 or better Or higher |
| | Construction of Self Contained Water Cooler | NA |
| Features and Performance | Mounting type | Floor mounted/Counter top |
| | Filtration capacity (In LPH) | Above 750 LPH and upto 1000 LPH |
| | Feed Water TDS (ppm) at which the machine LPH and Guaranteed output water quality is ensured | upto1500 |
| | Storage Water Tank (Inclusive in the scope of Supply) | No |
| | Storage Tank Material | NA |
| | Guaranteed output water quality | As per IS 10500 or better |
| Service, Warranty, Installation and Commissioning | Comprehensive warranty for complete unit | 1 year from the date of satisfactory commissioning of the machine |

| विवरण/Specification | विशिष्टि का नाम /Specification Name | बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values) |
|---------------------|--|---|
| | Minimum Free Services during Comprehensive warranty / CMC / AMC for complete unit | 4 nos. per year |
| | Installation and Commissioning inclusive in the scope of supply | Yes |
| | Training and Demonstration | The installation and demonstration of the machine at the consignee place shall be carried out as part of installation and commissioning |

Additional Specification Parameters - Reverse Osmosis Based Water Treatment System Above 50 LPH Capacity (V2) (1 pieces)

| Specification Parameter Name | Bid Requirement (Allowed Values) |
|------------------------------|---|
| NAME OF WORK | INVERSE ISSIMILATION SYSTEM 2000 LHP RO PLANT WITH CHILLER AND SHED |

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

| क्र.सं./S.No. | परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer | पता/Address | मात्रा /Quantity | डिलीवरी के दिन/Delivery Days |
|---------------|---|--|------------------|------------------------------|
| 1 | Santosh Panjabrao Zinje | 445001,Shri Vasant Rao Naik Govt Medical Collège & Hospital, Civil Line Waghapur Road Yavatmal | 1 | 15 |

Reverse Osmosis Based Water Treatment System Above 50 LPH Capacity (V2) (5 pieces)

तकनीकी विशिष्टियाँ /Technical Specifications

* [जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

| विवरण/Specification | विशिष्टि का नाम /Specification Name | बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values) |
|---------------------|--|---|
| Generic | Construction RO Frame | SS304 or better Or higher |
| | Construction of Body / Encloser | SS304 or better Or higher |
| | Construction of Self Contained Water Cooler | NA |

| विवरण/Specification | विशिष्टि का नाम /Specification Name | बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values) |
|---|---|---|
| Features and Performance | Mounting type | Floor mounted/Counter top |
| | Filtration capacity (In LPH) | Above 250 LPH and upto 500 LPH |
| | Feed Water TDS (ppm) at which the machine LPH and Guaranteed output water quality is ensured | upto1500 |
| | Storage Water Tank (Inclusive in the scope of Supply) | No |
| | Storage Tank Material | NA |
| | Guaranteed output water quality | As per IS 10500 or better |
| Service, Warranty, Installation and Commissioning | Comprehensive warranty for complete unit | 1 year from the date of satisfactory commissioning of the machine |
| | Minimum Free Services during Comprehensive warranty / CMC / AMC for complete unit | 4 nos. per year |
| | Installation and Commissioning inclusive in the scope of supply | Yes |
| | Training and Demonstration | The installation and demonstration of the machine at the consignee place shall be carried out as part of installation and commissioning |

Additional Specification Parameters - Reverse Osmosis Based Water Treatment System Above 50 LPH Capacity (V2) (5 pieces)

| Specification Parameter Name | Bid Requirement (Allowed Values) |
|------------------------------|---|
| NAME OF WORK | INVERSE ASSIMALATION 1000 LPH RO PLANT WITH CABIN POWDER COATED WITH WATER STORAGE TANK |

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

| क्र.सं./S.No. | परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer | पता/Address | मात्रा /Quantity | डिलीवरी के दिन/Delivery Days |
|---------------|---|---|------------------|------------------------------|
| 1 | Santosh Panjabrao Zinje | 445001,Shri Vasantnao Naik Govt Medical Collège & Hospital, Civil Line Waghapur Road Yavatmal | 5 | 15 |

| क्र.सं./S.N o. | परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer | पता/Address | मात्रा /Quantity | डिलीवरी के दिन/Delivery Days |
|-------------------|---|-------------|------------------|---------------------------------|
| | | | | |

Reverse Osmosis Based Water Treatment System Above 50 LPH Capacity (V2) (5 pieces)

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

| विवरण/Specification | विशिष्टि का नाम /Specification Name | बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values) |
|---|---|---|
| Generic | Construction RO Frame | SS202 or better, SS304 or better Or higher |
| | Construction of Body / Encloser | NA - Being without encloser, Food Grade Plastic or Better, SS202 or better, SS304 or better Or higher |
| | Construction of Self Contained Water Cooler | NA |
| Features and Performance | Mounting type | Floor mounted/Counter top |
| | Filtration capacity (In LPH) | Above 250 LPH and upto 500 LPH |
| | Feed Water TDS (ppm) at which the machine LPH and Guaranteed output water quality is ensured | upto1500 |
| | Storage Water Tank (Inclusive in the scope of Supply) | No |
| | Storage Tank Material | NA |
| | Guaranteed output water quality | As per IS 10500 or better |
| Service, Warranty, Installation and Commissioning | Comprehensive warranty for complete unit | 1 year from the date of satisfactory commissioning of the machine |
| | Minimum Free Services during Comprehensive warranty / CMC / AMC for complete unit | 4 nos. per year |
| | Installation and Commissioning inclusive in the scope of supply | Yes |
| | Training and Demonstration | The installation and demonstration of the machine at the consignee place shall be carried out as part of installation and commissioning |

Additional Specification Parameters - Reverse Osmosis Based Water Treatment System Above 50 LPH Capacity (V2) (5 pieces)

| Specification Parameter Name | Bid Requirement (Allowed Values) |
|------------------------------|--|
| NAME OF WORK | REVERSE OSMOSIS 1000 LPH RO PLANT WITH CABIN POWDER COATED WITH WATER STORAGE TANK |

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

| क्र.सं./S.No. | परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer | पता/Address | मात्रा /Quantity | डिलीवरी के दिन/Delivery Days |
|---------------|---|---|------------------|------------------------------|
| 1 | Santosh Panjabrao Zinje | 445001, Shri Vasant Rao Naik Govt Medical Collège & Hospital, Civil Line Waghapur Road Yavatmal | 5 | 15 |

Water Purification System With UV (Ultra-Violet Process) Or UV (Ultra-Violet Process)+UF (Ultra-Filtration Process) (V2) (5 pieces)

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम कैटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

| विवरण/Specification | विशिष्टि का नाम /Specification Name | बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values) |
|--------------------------|--|---|
| Features and Performance | Type of Water Purification Technology | Generally Conformity to IS 14724 for Ultraviolet (UV) |
| | Rate of Flow (In LPH) of purified water | upto 200 LPH |
| | Method of Mounting | Freestanding |
| | Guaranteed output water quality | As per IS 10500 or better |
| Water Storage | Storage Tank (inclusive in the scope of supply) | Self Contained Water Cooler |
| | Type of Water Tank / Location | Self Contained Water Cooler |
| | Storage Tank Material | Self Contained Water Cooler |
| | Storage Tank Capacity (in Ltr) | Self Contained Water Cooler |
| | Self Contained Water Cooler | Self Contained Water Cooler as per IS 1475 (ISI Marked) of cooling capacity - 40 LPH at Rated conditions and Storage Capacity 150 Liters (I,e 40/150 water cooler.) |

Additional Specification Parameters - Water Purification System With UV (Ultra-Violet Process) Or UV (Ultra-Violet Process)+UF (Ultra-Filtration Process) (V2) (5 pieces)

| Specification Parameter Name | Bid Requirement (Allowed Values) |
|------------------------------|--|
| NAME OF WORK | VERSE ASSIMALATION 500 LPH RO PLANT WITH CABIN POWDER COATED WITH WATER STORAGE TANK |

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

| क्र.सं./S.No. | परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer | पता/Address | मात्रा /Quantity | डिलीवरी के दिन/Delivery Days |
|---------------|---|---|------------------|------------------------------|
| 1 | Santosh Panjabrao Zinje | 445001,Shri Vasantnao Naik Govt Medical Collège & Hospital, Civil Line Waghapur Road Yavatmal | 5 | 15 |

Reverse Osmosis Based Water Treatment System Above 50 LPH Capacity (V2) (1 pieces)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

| विवरण/Specification | विशिष्टि का नाम /Specification Name | बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values) |
|--------------------------|---|---|
| Generic | Construction RO Frame | SS202 or better, SS304 or better Or higher |
| | Construction of Body / Encloser | NA - Being without encloser, Food Grade Plastic or Better, SS202 or better, SS304 or better Or higher |
| | Construction of Self Contained Water Cooler | NA |
| Features and Performance | Mounting type | Floor mounted/Counter top |
| | Filtration capacity (In LPH) | Above 500 LPH and upto 750 LPH |
| | Feed Water TDS (ppm) at which the machine LPH and Guaranteed output water quality is ensured | upto1500 |
| | Storage Water Tank (Inclusive in the scope of Supply) | No |
| | Storage Tank Material | NA |
| | Guaranteed output water quality | As per IS 10500 or better |

| विवरण/Specification | विशिष्टि का नाम /Specification Name | बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values) |
|---|--|---|
| Service, Warranty, Installation and Commissioning | Comprehensive warranty for complete unit | 1 year from the date of satisfactory commissioning of the machine |
| | Minimum Free Services during Comprehensive warranty / CMC / AMC for complete unit | 4 nos. per year |
| | Installation and Commissioning inclusive in the scope of supply | Yes |
| | Training and Demonstration | The installation and demonstration of the machine at the consignee place shall be carried out as part of installation and commissioning |

Additional Specification Parameters - Reverse Osmosis Based Water Treatment System Above 50 LPH Capacity (V2) (1 pieces)

| Specification Parameter Name | Bid Requirement (Allowed Values) |
|------------------------------|--|
| NAME OF WORK | REVERSE ASSIMILATION 500 LPH RO PLANT WITH CABIN POWDER COATED WITH WATER STORAGE TANK |

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

| क्र.सं./S.No. | परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer | पता/Address | मात्रा /Quantity | डिलीवरी के दिन/Delivery Days |
|---------------|---|--|------------------|------------------------------|
| 1 | Santosh Panjabrao Zinje | 445001,Shri Vasantao Naik Govt Medical Collège & Hospital, Civil Line Waghapur Road Yavatmal | 1 | 15 |

Water Purification System With UV (Ultra-Violet Process) Or UV (Ultra-Violet Process)+UF (Ultra-Filtration Process) (V2) (4 pieces)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

| विवरण/Specification | विशिष्टि का नाम /Specification Name | बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values) |
|--------------------------|--|---|
| Features and Performance | Type of Water Purification Technology | Generally Conformity to IS 14724 for Ultraviolet (UV) |

| विवरण/Specification | विशिष्टि का नाम /Specification Name | बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values) |
|---------------------|--|---|
| | Rate of Flow (In LPH) of purified water | upto 200 LPH |
| | Method of Mounting | Freestanding |
| | Guaranteed output water quality | As per IS 10500 or better |
| Water Storage | Storage Tank (inclusive in the scope of supply) | Self Contained Water Cooler |
| | Type of Water Tank / Location | Self Contained Water Cooler |
| | Storage Tank Material | Self Contained Water Cooler |
| | Storage Tank Capacity (in Ltr) | Self Contained Water Cooler |
| | Self Contained Water Cooler | Self Contained Water Cooler as per IS 1475 (ISI Marked) of cooling capacity - 60 LPH at Rated conditions and Storage Capacity 120 Liters (I,e 60/120 water cooler.) |

Additional Specification Parameters - Water Purification System With UV (Ultra-Violet Process) Or UV (Ultra-Violet Process)+UF (Ultra-Filtration Process) (V2) (4 pieces)

| Specification Parameter Name | Bid Requirement (Allowed Values) |
|------------------------------|--|
| NAME OF WORK | VERSE ASSIMALATION 500 LPH RO PLANT WITH CABIN POWDER COATED WITH WATER STORAGE TANK |

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

| क्र.सं./S.No. | परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer | पता/Address | मात्रा /Quantity | डिलीवरी के दिन/Delivery Days |
|---------------|---|---|------------------|------------------------------|
| 1 | Santosh Panjabrao Zinje | 445001,Shri Vasantnao Naik Govt Medical Collège & Hospital, Civil Line Waghapur Road Yavatmal | 4 | 15 |

Reverse Osmosis Based Water Treatment System Above 50 LPH Capacity (V2) (5 pieces)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

| विवरण/Specification | विशिष्टि का नाम /Specification Name | बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values) |
|---|---|---|
| Generic | Construction RO Frame | SS202 or better, SS304 or better Or higher |
| | Construction of Body / Encloser | NA - Being without encloser, Food Grade Plastic or Better, SS202 or better, SS304 or better Or higher |
| | Construction of Self Contained Water Cooler | NA |
| Features and Performance | Mounting type | Floor mounted/Counter top |
| | Filtration capacity (In LPH) | Above 250 LPH and upto 500 LPH, Above 750 LPH and upto 1000 LPH |
| | Feed Water TDS (ppm) at which the machine LPH and Guaranteed output water quality is ensured | upto 2000 |
| | Storage Water Tank (Inclusive in the scope of Supply) | No |
| | Storage Tank Material | NA |
| | Guaranteed output water quality | As per IS 10500 or better |
| Service, Warranty, Installation and Commissioning | Comprehensive warranty for complete unit | 1 year from the date of satisfactory commissioning of the machine |
| | Minimum Free Services during Comprehensive warranty / CMC / AMC for complete unit | 4 nos. per year |
| | Installation and Commissioning inclusive in the scope of supply | Yes |
| | Training and Demonstration | The installation and demonstration of the machine at the consignee place shall be carried out as part of installation and commissioning |

Additional Specification Parameters - Reverse Osmosis Based Water Treatment System Above 50 LPH Capacity (V2) (5 pieces)

| Specification Parameter Name | Bid Requirement (Allowed Values) |
|------------------------------|--|
| NAME OF WORK | VERSE ASSIMALATION 500 LPH RO PLANT WITH CABIN POWDER COATED WITH WATER STORAGE TANK |

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

| क्र.सं./S.No. | परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer | पता/Address | मात्रा /Quantity | डिलीवरी के दिन/Delivery Days |
|---------------|---|--|------------------|------------------------------|
| 1 | Santosh Panjabrao Zinje | 445001,Shri Vasantao Naik Govt Medical Collège & Hospital, Civil Line Waghapur Road Yavatmal | 5 | 15 |

Special terms and conditions-Version:1 effective from 03-04-2025 for category Reverse Osmosis based Water Treatment System above 50 LPH Capacity (V2)

1. Standard Terms and Conditions for Reverse Osmosis based Water Treatment System / Machine above 50 LPH Capacity

Scope of standard installation and commissioning for Reverse Osmosis based Water Treatment System / Machine above 50 LPH Capacity

1. Sellers Responsibility:

1. All the required tools and machinery as required for installation and commissioning of machine.
2. Suitable hardware including brackets / screws washers etc., for mounting and fitting of machine at the respective locations.
3. All the water connections / fittings piping shall be laid neatly, tidily and securely as per best industry practices.
4. They provide necessary piping and connections from inlet and outlet of the machine within 2~3 meters.
5. All electrical wiring / connection to ensure proper functioning of the machine.
6. All parts of the machine should be suitably earthed, and all electric wiring should be suitably insulated to avoid electric shock during usage.
7. During Service visits with a Comprehensive Warranty / CMC the following shall be applicable .
8. Changing of Pre-Filter during each visit free of cost.
9. Cleaning of the complete water purifications system along with the water tank (if applicable).
10. Changing of Complete Filters once a year free of cost which may include but not limited to Sand Filter, Sediment Filter, Carbon Filter, Mineral Filter, Micron Filter, Anti-Scaling, Alkaline Filter, Flushing Mechanism, Reject Water Control Mechanism, Mineralizer/Taste Enhancer Media, Activated Carbon Media, etc. (as applicable).
11. Seller shall ensure that the "Actual Filtration capacity (In LPH)" specified by them shall be in line with "Filtration capacity (In LPH)".In case any contradiction is observed the superior value out of two shall reveal.

2. Buyers Responsibility:

1. To provide all gate passes for the installation team to access the area where installation to be carried out.
2. To provide suitable location for installation of machine which having required and easy access during installation and post installation maintenance. Any civil work shall be responsible for buyer
3. To ensure inlet water supply within 2~3 meters of machine input and machine output.
4. To provide suitable power sockets within 1~2 meters of the machine.
5. To provide potable water of reasonable quality without having muddy appearance, solids and wastes etc. The input water is usually supplied from local municipalities or PHED supplies.
6. The Input water Head (pressure) shall be 0.3 kg (3-meter head).

3. Note to Sellers:

1. Seller may refer to GTC and ensure strict compliance of the uploaded/ offered product which shall be in line with their model having the claimed specifications in the catalogue or better.

2. Also, same model shall not be uploaded across catalogues with unreasonable/ contradictory offerings.

3. Sellers should note that while uploading the catalogue, all three images must be distinct.

1. **Image 1 - Should be Isometric View of the Complete Product**
2. **Image 2 - Front View of the Complete Product**
3. **Image 3 - LHS or RHS view of the Complete Product**
4. In case any discrepancy is observed in the offered/ uploaded products, OEM dashboard of the respective Brand may be removed, and account shall be suspended as per IM policy.

4. Note to Buyer:

1. For Procurement through BID/RA: - Buyers are advised to create bid with a specific value of Golden Parameter such as Mounting Type, Filtration capacity (In LPH), Maximum Feed Water TDS (ppm) at which the machine LPH and Guaranteed output water quality is ensured, Storage Tank Material, Storage Tank Capacity (In Liter), etc as applicable. Any bid created by the buyer without selecting specific LOV's or selecting Any Value in the above Golden Parameters will be treated as vague and is liable to be cancelled by competent authority at any point of time or if the above is resulting into limited competition or higher cost to the ex-chequer, the buyer will be solely responsible.
2. For Procurement through Direct / L1: - Buyers are advised to apply all filters and selections allowing all the values which are considered meeting or are better than their technical requirements. For example, Constructional Feature if the requirement is Complete Frame made of SS304 or better, buyer should select other superior values i.e. Complete Frame with encloser made of SS304 or better, such selection will act as Complete Frame made of SS304 or better (in L1 buying). For any violation of the above if resulting into limited competition or higher cost to the ex-chequer, the Buyer shall be solely
3. Buyers should also refer to GTC Clause 4. xiii.(w). The ATC / additional specification if any added by the buyer shall not be contradictory to the GeM category specifications / technical parameters (TP). Bids with contradictory specifications and technical parameters will be treated as vague and is liable to be cancelled by competent authority at any point of time or if the above is resulting into limited competition or higher cost to the ex-chequer, the buyer will be solely responsible.
4. Buyer/ consignee shall verify all the technical parameters and specifications including but limited to Filtration capacity (In LPH), Type of Machine and other related parameters of the supplied and installed machine as per contract before issuing
5. Buyers may consider EPBG for duration higher than machine warranty, which may be enched for inadequate warranty support.

Special terms and conditions-Version:1 effective from 25-07-2025 for category Water Purification System with UV (Ultra-Violet Process) or UV (Ultra-Violet Process)+UF (Ultra-Filtration Process) (V2)

1. Standard Terms & Conditions (STC) for Installation and Commissioning of Water Purification Systems - UV or UV + UF

Scope of Work - Installation & Commissioning:

This document outlines the standard installation and commissioning responsibilities for Water Purification Systems based on UV or a combination of UV and UF technologies.

1. **Responsibilities of the Seller:**
 1. Provision of all tools, equipment, and machinery required for installation and commissioning of the system.
 2. Supply of appropriate mounting hardware such as brackets, screws, washers, etc., for securing the machine at the designated location.
 3. Proper, clean, and secure piping and water connections should be installed as per industry best practices.
 4. Provision of inlet and outlet piping/connections within a range of 2-3 meters from the machine.
 5. Execution of all necessary electrical wiring to ensure correct and safe machine operation.
 6. Proper earthing of all machine components and insulation of electrical wiring to prevent electric shocks during use.
 7. During scheduled service visits under Comprehensive Warranty or CMC (Comprehensive Maintenance Contract), the following activities will be performed:
 - Replacement of pre-filter free of cost during every service visit.
 - Complete cleaning of the water purification system and associated water tank (if applicable).
 - Annual free replacement of all filters, which may include (but are not limited to): RO Filters, Sand Filter, Sediment Filter, UV, UF, Pre-Carbon Filter, Post-Carbon Filter, Mineral Filter, Micron Filter, Dual Media Filter, Anti-Scaling, Alkaline Filter, Absorption Filter, etc., as

applicable.

1. Responsibilities of the Buyer:

1. Facilitate access for the installation team by providing necessary gate passes to the installation site.
2. Ensure that the machine is installed at an accessible and appropriate location, suitable for both installation and future maintenance.
3. Ensure the availability of water supply inlet and outlet points within 1-2 meters of the machine.
4. Provide accessible electrical power sockets within 1-2 meters of the installation site.

1. Notes to Sellers:

1. Sellers must adhere to the General Terms and Conditions (GTC) and ensure the product matches the specifications listed in the catalogue or exceeds them.
2. A single model should not be uploaded under multiple catalogues with inconsistent or conflicting specifications.
3. The product must comply with CML specifications, including but not limited to LPH (litres per hour) capacity. Any discrepancies may trigger action as per the IM policy.
4. While uploading the product catalogue, sellers must include three distinct images:
 - Image 1: Isometric View of the Full Product
 - Image 2: Front View of the Full Product
 - Image 3: Left or Right Side View of the Full Product
5. If inconsistencies are found in the uploaded/offered product, the OEM dashboard for the concerned brand may be removed, and the seller account suspended in accordance with IM policy.

1. Notes to Buyers:

1. For Procurement via BID/RA:

- Buyers should create bids with clearly defined values for critical (“Golden”) parameters such as:
 - Type of Water Purification Technology
 - Filtration Capacity (in LPH)
 - Inclusion and specifications of Storage Tank
 - Material and Capacity of Storage Tank (in Liters)
 - Maximum Feed Water TDS (ppm) at which rated LPH, and water quality is assured
 - Guaranteed Output Water Quality
 - Bids lacking specific selections or choosing “Any Value” for these Golden Parameters may be deemed ambiguous and can be cancelled at any time by the competent authority. The buyer will be held accountable if vague specifications lead to reduced competition or increased cost to the exchequer.
2. Buyers are encouraged to apply comprehensive filters during BID/RA to include all qualifying options that meet or exceed technical requirements. For example, if a Semi-Automatic controller is required, options including Fully Automatic should also be selected. Failing to do so, resulting in restricted competition or higher procurement costs, shall be the buyer’s responsibility.
 3. Buyers must refer to Clause 4.xiii.(w) of the GTC. Any additional technical specifications added should not contradict GeM category standards. Contradictory specifications may render the bid invalid and subject to cancellation by competent authority.
 4. Before issuing the CRAC, the buyer/consignee must verify all technical specifications and parameters of the installed machine such as filtration capacity, machine type, etc., as per the contract.
 5. When sellers provide alternate models under the clause “Other Equivalent/Better Alternate Models Offered,” buyers must ensure that these models meet or exceed all original bid requirements before accepting them. This clause is relevant only in BID/RA-based procurement and does not apply to direct purchase or L1 procurement.
 6. Buyers may opt for an Extended Performance Bank Guarantee (EPBG) covering a period longer than the machine’s warranty, which may be invoked if warranty obligations are not met.

क्रेता द्वारा जोड़ी गई बिड की विशेष शर्तें/Buyer Added Bid Specific Terms and Conditions

1. Generic

OPTION CLAUSE: The Purchaser reserves the right to increase or decrease the quantity to be ordered up to 25 percent of bid quantity at the time of placement of contract. The purchaser also reserves the right to increase the ordered quantity up to 25% of the contracted quantity during the currency of the contract at the contracted rates. The delivery period of quantity shall commence from the last date of original delivery order and in cases where option clause is exercised during the extended delivery period the additional time shall commence from the last date of extended delivery period. The additional delivery time shall be $(\text{Increased quantity} \div \text{Original quantity}) \times \text{Original delivery period (in days)}$, subject to

minimum of 30 days. If the original delivery period is less than 30 days, the additional time equals the original delivery period. The Purchaser may extend this calculated delivery duration up to the original delivery period while exercising the option clause. Bidders must comply with these terms.

2. **Buyer Added Bid Specific ATC**

Buyer Added text based ATC clauses

1. Site Visit Report (SVR) Should be submit in technical bid.

The bidder should personally visit the RO Plant site with his architect and will have to uplod/ submit the G eo- tagged photographs of same along with the SVR. The should be countersigned by architect.

2. material agnest delevery payment 50 %

3. 2 years waranty and 3 years additional mentance well be included in this same tender price .

3. **Generic**

Actual delivery (and Installation & Commissioning (if covered in scope of supply)) is to be done at following address

THE LOCATON
BEING SPECIFIED
BY DEPARTMEN
TAKE THE SIDE SURVEY
WITH PROPER MANNER

4. **Generic**

Bidder financial standing: The bidder should not be under liquidation, court receivership or similar proceedings, should not be bankrupt. Bidder to upload undertaking to this effect with bid.

5. **Generic**

Bidders shall quote only those products (Part of Service delivery) in the bid which are not obsolete in the market and has at least 2 years residual market life i.e. the offered product shall not be declared end-of-life by the OEM before this period.

6. **Generic**

Bidders are advised to check applicable GST on their own before quoting. Buyer will not take any responsibility in this regards. GST reimbursement will be as per actuals or as per applicable rates (whichever is lower), subject to the maximum of quoted GST %.

7. **Generic**

Malicious Code Certificate:

The seller should upload following certificate in the bid:-

(a) This is to certify that the Hardware and the Software being offered, as part of the contract, does not contain Embedded Malicious code that would activate procedures to :-

- (i) Inhibit the desires and designed function of the equipment.
- (ii) Cause physical damage to the user or equipment during the exploitation.
- (iii) Tap information resident or transient in the equipment/network.

(b) The firm will be considered to be in breach of the procurement contract, in case physical damage, loss of information or infringements related to copyright and Intellectual Property Right (IPRs) are caused due to activation of any such malicious code in embedded software.

8. **Scope of Supply**

Scope of supply (Bid price to include all cost components) : Supply Installation Testing Commissioning of Goods and Training of operators and providing Statutory Clearances required (if any)

9. Turnover

Bidder Turn Over Criteria: The minimum average annual financial turnover of the bidder during the last three years, ending on 31st March of the previous financial year, should be as indicated in the bid document. Documentary evidence in the form of certified Audited Balance Sheets of relevant periods or a certificate from the Chartered Accountant / Cost Accountant indicating the turnover details for the relevant period shall be uploaded with the bid. In case the date of constitution / incorporation of the bidder is less than 3 year old, the average turnover in respect of the completed financial years after the date of constitution shall be taken into account for this criteria.

10. Certificates

Bidder's offer is liable to be rejected if they don't upload any of the certificates / documents sought in the Bid document, ATC and Corrigendum if any.

11. Certificates

ISO 9001: The bidder or the OEM of the offered products must have ISO 9001 certification.

12. Certificates

Material Test Certificate Should Be Sent Along with The Supply. The Material Will Be Checked by Buyer's Lab & the Results of the Lab will be the Sole Criteria for Acceptance of the Item.

13. Certificates

The bidder is required to upload, along with the bid, all relevant certificates such as BIS licence, type test certificate, approval certificates and other certificates as prescribed in the Product Specification given in the bid document.

14. Certificates

To be eligible for award of contract, Bidder / OEM must possess following Certificates / Test Reports on the date of bid opening (to be uploaded with bid):

YES

.

15. Service & Support

Availability of Service Centres: Bidder/OEM must have a Functional Service Centre in the State of each Consignee's Location in case of carry-in warranty. (Not applicable in case of goods having on-site warranty). If service center is not already there at the time of bidding, successful bidder / OEM shall have to establish one within 30 days of award of contract. Payment shall be released only after submission of documentary evidence of having Functional Service Centre.

16. Service & Support

Dedicated /toll Free Telephone No. for Service Support : BIDDER/OEM must have Dedicated/toll Free Telephone No. for Service Support.

17. Service & Support

Escalation Matrix For Service Support : Bidder/OEM must provide Escalation Matrix of Telephone Numbers for Service Support.

18. Financial Criteria

NET WORTH: Net Worth of the OEM should be positive as per the last audited financial statement.

19. Buyer Added Bid Specific ATC

Buyer uploaded ATC document [Click here to view the file.](#)

अस्वीकरण/Disclaimer

The additional terms and conditions have been incorporated by the Buyer after approval of the Competent Authority in Buyer Organization, whereby Buyer organization is solely responsible for the impact of these clauses on the bidding process, its outcome, and consequences thereof including any eccentricity / restriction arising in the bidding process due to these ATCs and due to modification of technical specifications and / or terms and conditions governing the bid. If any clause(s) is / are incorporated by the Buyer regarding following, the bid and resultant contracts shall be treated as null and void and such bids may be cancelled by GeM at any stage of bidding process without any notice:-

1. Definition of Class I and Class II suppliers in the bid not in line with the extant Order / Office Memorandum issued by DPIIT in this regard.
2. Seeking EMD submission from bidder(s), including via Additional Terms & Conditions, in contravention to exemption provided to such sellers under GeM GTC.
3. Publishing Custom / BOQ bids for items for which regular GeM categories are available without any Category item bunched with it.
4. Creating BoQ bid for single item.
5. Mentioning specific Brand or Make or Model or Manufacturer or Dealer name.
6. Mandating submission of documents in physical form as a pre-requisite to qualify bidders.
7. Floating / creation of work contracts as Custom Bids in Services.
8. Seeking sample with bid or approval of samples during bid evaluation process. (However, in bids for [attached categories](#), trials are allowed as per approved procurement policy of the buyer nodal Ministries)
9. Mandating foreign / international certifications even in case of existence of Indian Standards without specifying equivalent Indian Certification / standards.
10. Seeking experience from specific organization / department / institute only or from foreign / export experience.
11. Creating bid for items from irrelevant categories.
12. Incorporating any clause against the MSME policy and Preference to Make in India Policy.
13. Reference of conditions published on any external site or reference to external documents/clauses.
14. Asking for any Tender fee / Bid Participation fee / Auction fee in case of Bids / Forward Auction, as the case may be.
15. Buyer added ATC Clauses which are in contravention of clauses defined by buyer in system generated bid template as indicated above in the Bid Details section, EMD Detail, ePBG Detail and MII and MSE Purchase Preference sections of the bid, unless otherwise allowed by GeM GTC.
16. In a category based bid, adding additional items, through buyer added additional scope of work/ additional terms and conditions/or any other document. If buyer needs more items along with the main item, the same must be added through bunching category based items or by bunching custom catalogs or bunching a BoQ with the main category based item, the same must not be done through ATC or Scope of Work.

Further, if any seller has any objection/grievance against these additional clauses or otherwise on any aspect of this bid, they can raise their representation against the same by using the Representation window provided in the bid details field in Seller dashboard after logging in as a seller within 4 days of bid publication on GeM. Buyer is duty bound to reply to all such representations and would not be allowed to open bids if he fails to reply to such representations.

All GeM Sellers / Service Providers are mandated to ensure compliance with all the applicable laws / acts / rules including but not limited to all Labour Laws such as The Minimum Wages Act, 1948, The Payment of Wages Act, 1936, The Payment of Bonus Act, 1965, The Equal Remuneration Act, 1976, The Payment of Gratuity Act, 1972 etc. Any non-compliance will be treated as breach of contract and Buyer may take suitable actions as per GeM Contract.

यह बिड सामान्य शर्तों के अंतर्गत भी शासित है /This Bid is also governed by the General Terms and Conditions

जेम की सामान्य शर्तों के खंड 26 के संदर्भ में भारत के साथ भूमि सीमा साझा करने वाले देश के बिडर से खरीद पर प्रतिबंध के संबंध में भारत के साथ भूमि सीमा साझा करने वाले देश का कोई भी बिडर इस निविदा में बिड देने के लिए तभी पात्र होगा जब वह बिड देने वाला सक्षम प्राधिकारी के पास पंजीकृत हो। बिड में भाग लेते समय बिडर को इसका अनुपालन करना होगा और कोई भी गलत घोषणा किए जाने व इसका अनुपालन न करने पर अनुबंध को तत्काल समाप्त करने और कानून के अनुसार आगे की कानूनी कार्रवाई का आधार होगा।/In terms of GeM GTC clause 26 regarding Restrictions on procurement from a bidder of a country which shares a land border with India, any bidder from a country which shares a land border with India will be eligible to bid in this tender only if the bidder is registered with the Competent Authority. While participating in bid, Bidder has to undertake compliance of this and any false declaration and non-compliance of this would be a ground for immediate termination of the contract and further legal action in accordance with the laws.

---धन्यवाद/Thank You---