

**बिड दस्तावेज़ / Bid Document**

बिड विवरण/Bid Details	
बिड बंद होने की तारीख/समय /Bid End Date/Time	12-12-2025 11:00:00
बिड खुलने की तारीख/समय /Bid Opening Date/Time	12-12-2025 11:30:00
बिड पेशकश वैधता (बंद होने की तारीख से)/Bid Offer Validity (From End Date)	120 (Days)
मंत्रालय/राज्य का नाम/Ministry/State Name	Ministry Of Coal
विभाग का नाम/Department Name	Coal India Limited
संगठन का नाम/Organisation Name	Central Coalfields Limited
कार्यालय का नाम/Office Name	Central Coalfields Limited Ranchi Jharkhand
कुल मात्रा/Total Quantity	1
वस्तु श्रेणी /Item Category	Power Generator - DG Set (up to 900 KVA) (Q2)
एमएसएमई के लिए अनुभव के वर्षों और टर्नओवर से छूट प्रदान की गई है/MSE Exemption for Years of Experience and Turnover	No
स्टार्टअप के लिए अनुभव के वर्षों और टर्नओवर से छूट प्रदान की गई है /Startup Exemption for Years of Experience and Turnover	No
विक्रेता से मांगे गए दस्तावेज़/Document required from seller	Certificate (Requested in ATC) *In case any bidder is seeking exemption from Experience / Turnover Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer
क्या आप निविदाकारों द्वारा अपलोड किए गए दस्तावेजों को निविदा में भाग लेने वाले सभी निविदाकारों को दिखाना चाहते हैं? संदर्भ मेनू है/Do you want to show documents uploaded by bidders to all bidders participated in bid?	Yes (Documents submitted as part of a clarification or representation during the tender/bid process will also be displayed to other participated bidders after log in)
बिड लगाने की समय सीमा स्वतः नहीं बढ़ाने के लिए आवश्यक बिड की संख्या। / Minimum number of bids required to disable automatic bid extension	3
दिनों की संख्या, जिनके लिए बिड लगाने की समय-सीमा बढ़ाई जाएगी। / Number of days for which Bid would be auto-extended	7

बिड विवरण/Bid Details	
ऑटो एक्सटेंशन अधिकतम कितनी बार किया जाना है। / <b>Number of Auto Extension count</b>	1
बिड से रिवर्स नीलामी सक्रिय किया/Bid to RA enabled	No
बिड का प्रकार/Type of Bid	Two Packet Bid
तकनीकी मूल्यांकन के दौरान तकनीकी स्पष्टीकरण हेतु अनुमत समय /Time allowed for Technical Clarifications during technical evaluation	7 Days
निरीक्षण आवश्यक (सूचीबद्ध निरीक्षण प्राधिकरण /जेम के साथ पूर्व पंजीकृत एजेंसियों द्वारा)/Inspection Required (By Empanelled Inspection Authority / Agencies pre-registered with GeM)	No
अनुमानित बिड मूल्य /Estimated Bid Value	342000
Payment Timelines	Payments shall be made to the Seller within <b>21</b> days of issue of consignee receipt-cum-acceptance certificate (CRAC) and on-line submission of bills (This is in supersession of 10 days time as provided in clause 12 of GeM GTC)
मूल्यांकन पद्धति/Evaluation Method	Total value wise evaluation
मध्यस्थता खंड/Arbitration Clause	No
सुलह खंड/Mediation Clause	No

#### ईएमडी विवरण/EMD Detail

आवश्यकता/Required	No
-------------------	----

#### ईपीबीजी विवरण /ePBG Detail

आवश्यकता/Required	No
-------------------	----

बोली विभाजन लागू नहीं किया गया/ Bid splitting not applied.

#### एमआईआई खरीद वरीयता/MII Purchase Preference

एमआईआई खरीद वरीयता/MII Purchase Preference	No
--	----

#### एमएसई खरीद वरीयता/MSE Purchase Preference

एमएसई खरीद वरीयता/MSE Purchase Preference	Yes
---	-----

सूक्ष्म और लघु उद्यम मूल उपकरण निर्माताओं को खरीद में प्राथमिकता, यदि उनका मूल्य L1+X% तक की सीमा में हो / Purchase Preference to MSE OEMs available upto price within L1+X%	15
सूक्ष्म और लघु उद्यम को खरीद में प्राथमिकता के लिए बिड की मात्रा का अधिकतम प्रतिशत / Maximum Percentage of Bid quantity for MSE purchase preference	25

1. Purchase preference will be given to MSEs having valid Udyam Registration and whose credentials are validated online through Udyam Registration portal as defined in Public Procurement Policy for Micro and Small Enterprises (MSEs) Order, 2012 dated 23.03.2012 issued by Ministry of Micro, Small and Medium Enterprises and its subsequent Orders/Notifications issued by concerned Ministry. If the bidder wants to avail themselves of the Purchase preference, the bidder must be the manufacturer / OEM of the offered product on GeM. Traders are excluded from the purview of Public Procurement Policy for Micro and Small Enterprises and hence resellers offering products manufactured by some other OEM are not eligible for any purchase preference. In respect of bid for Services, the bidder must be the Service provider of the offered Service. Relevant documentary evidence in this regard shall be uploaded along with the bid in respect of the offered product or service and Buyer will decide eligibility for purchase preference based on documentary evidence submitted, while evaluating the bid. If L-1 is not an MSE and MSE Seller (s) has / have quoted price within L-1+ 15% (Selected by Buyer) of margin of purchase preference /price band defined in relevant policy, such MSE Seller shall be given opportunity to match L-1 price and contract will be awarded for 25% (selected by Buyer) percentage of total quantity. The buyers are advised to refer the OM No. F.1/4/2021-PPD dated 18.05.2023 [OM No.1 4 2021 PPD dated 18.05.2023](#) for compliance of Concurrent application of Public Procurement Policy for Micro and Small Enterprises Order, 2012 and Public Procurement (Preference to Make in India) Order, 2017. Benefits of MSE will be allowed only if seller is validated on-line in GeM profile as well as validated and approved by Buyer after evaluation of documents submitted.

2. Estimated Bid Value indicated above is being declared solely for the purpose of guidance on EMD amount and for determining the Eligibility Criteria related to Turn Over, Past Performance and Project / Past Experience etc. This has no relevance or bearing on the price to be quoted by the bidders and is also not going to have any impact on bid participation. Also this is not going to be used as a criteria in determining reasonableness of quoted prices which would be determined by the buyer based on its own assessment of reasonableness and based on competitive prices received in Bid / RA process.

## Power Generator - DG Set (up To 900 KVA) ( 1 pieces )

### तकनीकी विशिष्टियाँ /Technical Specifications

[\\* जेम कैटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
Power Generator INSTALLATION CONFIGURATIONS	<b>Power Generator installation configurations as defined in CPWD General Specifications for Electrical works - Part VII (DG Set)</b>	Fixed (Power Generators are permanently installed)"
OUTPUT CAPACITY RATING/ PHASE	<b>Nominal Rated Capacity (kVA)</b>	15
	No of Phase (Single Phase-3-5kVA) (Single Phase or Three Phase-5 & 7-5, 10,15, 20, 25, 30 & 40 kVA) (Three Phase-50 to 900 kVA)	Three Phase

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
ENGINE	<b>Rated Engine Power (kWm)</b>	100 % of the required powered at STP(Standard Temperature Pressure) i.e equal to (Nominal Rated Capacity (KVA) of power generator + Any Auxiliary power Consumption by the Power generator) x Power factor(0.8) / Alternator efficiency, 110 % of the required powered at STP(Standard Temperature Pressure) i.e equal to (Nominal Rated Capacity (KVA) of power generator Any Auxiliary power Consumption by the Power generator) x Power factor(0.8) / Alternator efficiency Or higher
	Type of Engine cooling	Liquid Cooled
	<b>Type of governer</b>	Electronic Or higher
	Number of cylinders (nos)	2
	<b>Rated RPM of Engine (RPM)</b>	1500
	<b>Fuel</b>	High Speed Diesel (HSD)
	Starting voltage (volt)	12
	Salient Features of Engine	Turbo Charged Engine, Naturally aspirated engine, Direct injection Fuel System, CRDi Fuel System, cold start upto (-20 deg c ), No derating applicable upto 4500 above MSL of altitude at 25 degree celcius, Indirect injection (IDI) Fuel System, Ambient working temperature upto 55 degree celcius.
GOVERNING CLASS	"Maximum Change of Speed as a Percentage of Rated Speed on suddenly taking-off the rated load(Transient) "	15
	"Maximum Recovery Time in Seconds on suddenly taking-off the rated load(Transient) "	15.0 <b>(second)</b>
	Maximum Change of Speed as a Percentage of Rated Speed on suddenly taking-off the rated load(Permanent)	5
	"Maximum Change of Speed as a Percentage of Rated Speed On a change of load, both on and off, by all steps of 25 percent of the rated load (Transient) "	4
	"Maximum Recovery Time in Seconds on a change of load, both on and off, by all steps of 25 percent of the rated load(Transient) "	5.0 <b>(second)</b>
	"Maximum Change of Speed as a Percentage of Rated Speed On a change of load, both on and off, by all steps of 25 percent of the rated load (Permanent)	1.5

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
ALTERNATOR	Alternator Voltage Rating	415.0 ( <b>Volt</b> )
	Efficiency at rated Power factor at 75% of full Load	90.0 - 100.0 Or higher ( <b>percent</b> )
	Conformity to Indian Standard (for Alternator)	Generally conforming to IS:13364 (Part-1) latest (Upto 20 kVA)
	<b>Voltage Regulation Grade</b>	VG 3 Or higher
	Alternator IP Rating	IP 23 Or higher
	Salient features of Alternator	Resistance Temperature Detectors (RTD), Bearing Temperature Detectors (BTD), space heater, NA
CONTROL PANEL	<b>Control Panel</b>	Manual Control Panel
	Control Panel Location	Inside the canopy
	IP Rating of Control Panel	IP 53, IP 54, IP 55 Or higher
	Display meters in the control panel (with appropriate rating and accuracy class ) - inclusive in the scope of supply	Voltmeter, Ammeter, Frequency meter, Power Factor meter, Multifunctional Digital display meter (displaying Voltage, Current, Frequency, Power Factor)
	Other devices in the control panel (with appropriate rating) - inclusive in the scope of supply	Required switches and cutout, MCB, MCCB, Contactor, Circuit breaker, Battery charger, remote monitoring over internet with GSM modem.
	Displayed parameters/Features	Engine Speed, Lube oil pressure, Coolant/cylinder head Temperature, Engine running hours, Engine battery voltage, Engine Running status, Generator Voltage (Ph-Ph), Generator Voltage (Ph-N), Generator Current (R, Y, B), Generator apparent Power (kVA), Generator active Power (kW), Powerfactor, Frequency, Fuel level, Event log, Control supply Voltage, Temperature scanner (RTD,BTD)
	Indicators	Low Lube oil pressure, High water / coolant / cylinder head temperature, Low fuel level, Over speed
	Audio Alarm	Low Lube oil pressure, High water / coolant / cylinder head temperature, Low fuel level, Over speed
ACOUSTIC ENCLOSURE	Sheet Thickness(mm)	1.6, 1.8, 2 Or higher
	Thickness of insulation	50.0 - 120.0 Or higher ( <b>millimeter</b> )
	Density of insulation (kg/cubic m)	32.0 - 100.0 Or higher
	Noise level at 1 meter (dB)	75
Fuel Tank	Fuel Tank Capacity	90.0 ( <b>liter</b> )
	Number of Fuel tank	1
	Fuel Tank Sheet Material Thickness(mm)	2, 3 Or higher
	Fuel Tank Features	Fuel Tank capacity is sufficient for 8 hrs of running at full load

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
BATTERY	Battery Type & Specification	Normal lead acid to IS: 7372 for motor vehicles
	Battery capacity (Ah)	90
	No of batteries	1
SALIENT FEATURES	Salient Features of Power Generator	Glass window on Accoustic Enclosure in front of the Control Panel, Emergency Stop outside the Accoustic Enclosure
TRAILER	<b>Trailer</b>	Yes
	<b>Pay load of the Trailer</b>	0, 500, 1000, 2000 Or higher <b>(kilogram)</b>
	Salient Features of trailer	suitable Mounting jack, suitable reflectors, suitable parking brakes, suitable earthing spikes, NA
SCOPE OF INSTALLATION	<b>Installation</b>	Without installation, with installation - inclusive in the scope of supply Or higher
	Scope of installation for Diesel Generating Set when offered by the vendor - inclusive in the scope of supply(Part-1)	a) Installation of Power Generator when offered by the vendor is inclusive in the scope of supply and shall be done by the seller. The installation work of Power Generator and its constituent parts shall be generally conforming to CPWD General Specification for Electrical Works, Part - VII - latest. b) Foundation shall be constructed by the seller. Foundation shall be of PCC type with the ratio of 4:2:1. The length and breadth of the foundation shall be 300 mm more from the respective length and breadth of the Power Generator. The height of the foundation shall be 400 mm, i.e., 200 mm below and 200 mm above the ground level. All the materials / labour required for foundation work shall be supplied by the seller.
	Scope of installation for Diesel Generating Set when offered by the vendor - inclusive in the scope of supply(Part-2)	c) Supply, laying and termination of interconnecting power and control cable shall be done by the seller. The cable supplied shall be ISI marked heavy duty PVC insulated, armoured cable, with PVC outer Sheath of Type ST-2 (FR Grade, Category C1), with aluminium conductor having insulation of PVC compound type -C, suitable for rated voltage upto and including 1100 volts and conforming to IS: 1554 (Part-1) latest. For 3-Phase Power Generators, 3.5 core or higher core cables shall be used. Total length of the cable supplied by the seller shall be within 30 meters for each Power Generator with manual control panel and within 60 metres for each Power Generator with AMF control panel. The current rating of the cables shall be as indicated below: 2C, 6 Sq mm for Single Phase, 3.5 & 5.0 KVA 2C, 10 Sq mm for Single Phase, 7.5 & 10 KVA 2C, 25 Sq mm for Single Phase, 15 KVA 2C, 35 Sq mm for Single Phase, 20 KVA 2C, 70Sq mm for Single Phase, 25 KVA 2C, 95Sq mm for Single Phase, 30 KVA 2C, 120Sq mm for Single Phase, 40 KVA 4C, 4 Sq mm for Three Phase,

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
	Scope of installation for Diesel Generating Set when offered by the vendor - inclusive in the scope of supply(Part-3)	d) 10 KVA 4C, 6 Sq mm for Three Phase, 15 KVA 4C, 10 Sq mm for Three Phase, 20 & 25 KVA 4C, 16 Sq mm for Three Phase, 30 KVA 3.5C, 25 Sq mm for Three Phase, 40 KVA 3.5C, 35 Sq mm for Three Phase, 50 KVA 3.5C, 70 Sq mm for Three Phase, 62.5 & 75 KVA 3.5C, 95 Sq mm for Three Phase, 82.5 KVA 3.5C, 120 Sq mm for Three Phase, 100 KVA 3.5C, 185 Sq mm for Three Phase, 125 KVA 3.5C, 300 Sq mm for Three Phase, 160 KVA 3.5C, 2 Run of 120 Sq mm for Three Phase, 180 KVA 3.5C, 2 Run of 150 Sq mm for Three Phase, 200 KVA 3.5C, 2 Run of 185 Sq mm for Three Phase, 225 KVA 3.5C, 2 Run of 240 Sq mm for Three Phase, 250 & 275 KVA 3.5C, 3 Run of 185 Sq mm for Three Phase, 320 KVA 3.5C, 3 Run of 240 Sq mm for Three Phase, 380 & 400 KVA 3.5C, 4 Run of 240 Sq mm for Three Phase, 500, 600 & 750 KVA 3.5C, 6 Run of 240 Sq mm for Three Phase, 900 KVA
	Scope of installation for Diesel Generating Set when offered by the vendor - inclusive in the scope of supply(Part-4)	e) Construction of suitable earthing station and necessary connections shall be done by the seller. All the materials / labour required for construction of earthing station shall be supplied by the seller. The total number of earthing pits/stations shall be 4, i.e., 2 for neutral and 2 for body-earthing. Netutral earthing shall be done with copper Plate and Body earthing shall be done with G.I. plate / Copper. The consignee should choose installation site in such a way that the earthing stations can be made within 10 metres of the Power Generator. Earthing station shall be typically constructed as per prevalent standard practices and shall be generally conforming to CPWD General specification for Electrical Works, Part - VII & Part - I - latest. e) Installation of Fuel Tank including foundation / stand shall be done by the seller. f)The warranty is applicable upto specified value of month/hours whichever occurs first's.
	Above Scope of installation for Diesel Generating Set when offered by the vendor has been seen, read, understood and agreed to comply	Yes
WARRANTY/SERVICE S	<b>Warranty on Complete power genertor/DG Set</b>	24, 36 Or higher <b>(month)</b>
	Warranty in running hours	5000.0 - 5000.0 Or higher <b>(hour)</b>
	<b>Number of preventive maintenance visits offered in an year during warranty period (Supply of all consumables is the buyer's responsibilty)*</b>	2
TEST REPORTS	Type of lab which carried out Test of Complete Product to prove the conformity of product as per specification	Certificates required as per CPCB, Govt Lab, NABL accredited lab, NA

विवरण/Specification	विशिष्ट का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
	<b>Test report Available for (Test/approval)</b>	Type Approval Certificate for the specified rating of the Power Generator from any of the designated agency authorized by CPCB, COP Certificate for engine, Type test report and Endurance test report for Engine as per IS: 10001 latest / IS: 10002 latest, Type test report for Alternator as per IS:13364 (Part-1) latest / IS:13364 (Part-2) latest to prove conformity to the specifications
	Agree to provide all relevant documents Test Report/supporting document /reports etc to the buyer at the time of bidding or on demand	YES

**प्रेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity**

क्र.सं./S.N o.	प्रेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Kumar Gautam Ranjan	825314,Regional Store Parej CCL P.O. Ghatotand , Ramgarh- 825314.	1	60

**क्रेता द्वारा जोड़ी गई बिड की विशेष शर्तें/Buyer Added Bid Specific Terms and Conditions**

**1. Generic**

OPTION CLAUSE: The Purchaser reserves the right to increase or decrease the quantity to be ordered up to 25 percent of bid quantity at the time of placement of contract. The purchaser also reserves the right to increase the ordered quantity up to 25% of the contracted quantity during the currency of the contract at the contracted rates. The delivery period of quantity shall commence from the last date of original delivery order and in cases where option clause is exercised during the extended delivery period the additional time shall commence from the last date of extended delivery period. The additional delivery time shall be  $(\text{Increased quantity} \div \text{Original quantity}) \times \text{Original delivery period (in days)}$ , subject to minimum of 30 days. If the original delivery period is less than 30 days, the additional time equals the original delivery period. The Purchaser may extend this calculated delivery duration up to the original delivery period while exercising the option clause. Bidders must comply with these terms.

**2. Generic**

Bidder shall submit the following documents along with their bid for Vendor Code Creation:

- Copy of PAN Card.
- Copy of GSTIN.
- Copy of Cancelled Cheque.



d. Copy of EFT Mandate duly certified by Bank.

### 3. **Certificates**

Bidder's offer is liable to be rejected if they don't upload any of the certificates / documents sought in the Bid document, ATC and Corrigendum if any.

### 4. **Buyer Added Bid Specific ATC**

Buyer uploaded ATC document [Click here to view the file.](#)

## अस्वीकरण/**Disclaimer**

The additional terms and conditions have been incorporated by the Buyer after approval of the Competent Authority in Buyer Organization, whereby Buyer organization is solely responsible for the impact of these clauses on the bidding process, its outcome, and consequences thereof including any eccentricity / restriction arising in the bidding process due to these ATCs and due to modification of technical specifications and / or terms and conditions governing the bid. If any clause(s) is / are incorporated by the Buyer regarding following, the bid and resultant contracts shall be treated as null and void and such bids may be cancelled by GeM at any stage of bidding process without any notice:-

1. Definition of Class I and Class II suppliers in the bid not in line with the extant Order / Office Memorandum issued by DPIIT in this regard.
2. Seeking EMD submission from bidder(s), including via Additional Terms & Conditions, in contravention to exemption provided to such sellers under GeM GTC.
3. Publishing Custom / BOQ bids for items for which regular GeM categories are available without any Category item bunched with it.
4. Creating BoQ bid for single item.
5. Mentioning specific Brand or Make or Model or Manufacturer or Dealer name.
6. Mandating submission of documents in physical form as a pre-requisite to qualify bidders.
7. Floating / creation of work contracts as Custom Bids in Services.
8. Seeking sample with bid or approval of samples during bid evaluation process. (However, in bids for [attached categories](#), trials are allowed as per approved procurement policy of the buyer nodal Ministries)
9. Mandating foreign / international certifications even in case of existence of Indian Standards without specifying equivalent Indian Certification / standards.
10. Seeking experience from specific organization / department / institute only or from foreign / export experience.
11. Creating bid for items from irrelevant categories.
12. Incorporating any clause against the MSME policy and Preference to Make in India Policy.
13. Reference of conditions published on any external site or reference to external documents/clauses.
14. Asking for any Tender fee / Bid Participation fee / Auction fee in case of Bids / Forward Auction, as the case may be.
15. Buyer added ATC Clauses which are in contravention of clauses defined by buyer in system generated bid template as indicated above in the Bid Details section, EMD Detail, ePBG Detail and MII and MSE Purchase Preference sections of the bid, unless otherwise allowed by GeM GTC.
16. In a category based bid, adding additional items, through buyer added additional scope of work/ additional terms and conditions/or any other document. If buyer needs more items along with the main item, the same must be added through bunching category based items or by bunching custom catalogs or bunching a BoQ with the main category based item, the same must not be done through ATC or Scope of Work.

Further, if any seller has any objection/grievance against these additional clauses or otherwise on any aspect of this bid, they can raise their representation against the same by using the Representation window provided in the bid details field in Seller dashboard after logging in as a seller within 4 days of bid publication on GeM. Buyer is duty bound to reply to all such representations and would not be allowed to open bids if he fails to reply to such representations.

**All GeM Sellers/Service Providers shall ensure full compliance with all applicable labour laws, including the provisions, rules, schemes and guidelines under the four Labour Codes i.e. the Code on Wages, 2019; the Industrial Relations Code, 2020; the Occupational Safety, Health and Working Conditions Code, 2020; and the Code on Social Security, 2020 as and when notified and brought into force by the Government of India.**

**For all provisions of the Labour Codes that are pending operationalisation through rules, schemes or notifications, the corresponding provisions of the pre-existing labour enactments (such as The Minimum Wages Act, 1948, The Payment of Wages Act, 1936, The Payment of Bonus Act, 1965, The Equal Remuneration Act, 1976, The Payment of Gratuity Act, 1972, etc. and relevant State Rules) shall continue to remain applicable.**

**The Seller/ Service Providers shall, therefore, be responsible for ensuring compliance under:**

- **All notified and enforceable provisions of the new Labour Codes as mentioned hereinabove; and**
- **All operative provisions of the erstwhile Labour Laws until their complete substitution.**

**All obligations relating to wages, social security, safety, working conditions, industrial relations etc. and any other statutory requirements shall be strictly met by the Seller/ Service Provider. Any non-compliance shall constitute a breach of the contract and shall entitle the Buyer to take appropriate action in accordance with the contract and applicable law.**

[यह बिड सामान्य शर्तों के अंतर्गत भी शासित है /This Bid is also governed by the General Terms and Conditions](#)

जेम की सामान्य शर्तों के खंड 26 के संदर्भ में भारत के साथ भूमि सीमा साझा करने वाले देश के बिडर से खरीद पर प्रतिबंध के संबंध में भारत के साथ भूमि सीमा साझा करने वाले देश का कोई भी बिडर इस निविदा में बिड देने के लिए तभी पात्र होगा जब वह बिड देने वाला सक्षम प्राधिकारी के पास पंजीकृत हो। बिड में भाग लेते समय बिडर को इसका अनुपालन करना होगा और कोई भी गलत घोषणा किए जाने व इसका अनुपालन न करने पर अनुबंध को तत्काल समाप्त करने और कानून के अनुसार आगे की कानूनी कार्यवाई का आधार होगा।/In terms of GeM GTC clause 26 regarding Restrictions on procurement from a bidder of a country which shares a land border with India, any bidder from a country which shares a land border with India will be eligible to bid in this tender only if the bidder is registered with the Competent Authority. While participating in bid, Bidder has to undertake compliance of this and any false declaration and non-compliance of this would be a ground for immediate termination of the contract and further legal action in accordance with the laws.

**---धन्यवाद/Thank You---**